

SCHOOL:	Bass High School (8223)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Bankstown
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Staff Study - (18.59 SQM)	Office (4)	
B00A - R0006 - Special Learning Space - (52.15 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0007 - Special Learning Space - (52 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0008 - Special Learning Space - (51.93 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0009 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0011 - Deputy Principal Office - (12.57 SQM)	Office (3)	
B00A - R0014 - Staff Study - (15.87 SQM)	Office (3)	
B00A - R0016 - Principal Office - (17.62 SQM)	Office (4)	
B00A - R0028 - Deputy Principal Office - (12.61 SQM)	Office (3)	
B00A - R0033 - Public Reception - (27.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Student Waiting - (26.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Leading Teacher - (9.63 SQM)	Office (2)	
B00A - R0037 - Deputy Principal Office - (9.72 SQM)	Office (2)	
B00A - R0038 - Clinic - Boys - (8.4 SQM)	Office (2)	
B00A - R0039 - Interview/Office - Type 1 - (10.61 SQM)	Office (2)	
B00A - R0040 - Movement - (77.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Administration - Clerical - (35.18 SQM)	Office (8)	
B00A - R1003 - General Learning Space - (52.22 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R1004 - General Learning Space - (52 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R1005 - General Learning Space - (52.22 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R1006 - General Learning Space - (52 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R1007 - Multi Media Workshop - (24.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Dark Room - (27.05 SQM)	Office (6)	
B00A - R1009 - Art Learning Space - (64.05 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R1013 - Art Learning Space - (65.69 SQM) - Teaching Space: 1	Student Space (65)	
B00A - R1014 - Movement - (85.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Movement - (44.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Food Technology L.S. - (63.7 SQM) - Teaching Space: 1	Student Space (65)	
B00B - R0018 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Staff Kitchen - (11.25 SQM)	Office (2)	
B00B - R0020 - Commonroom - (74.4 SQM)	Office (18)	
B00B - R0021 - Movement - (37.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Seminar - (25.35 SQM)	Office (6)	
B00B - R0023 - Food Technology L.S. - (90.54 SQM) - Teaching Space: 1	Student Space (71)	
B00B - R0027 - Preparation - Materials - (24.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Student Reception - (13.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Movement - (27.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - General Learning Space - (78.33 SQM) - Teaching Space: 1	Student Space (53)	
B00B - R1010 - Design/Technology L.S. - (65.08 SQM) - Teaching Space: 1	Student Space (65)	
B00B - R1013 - Movement - (75.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Staff Study - (23.75 SQM)	Office (5)	
B00B - R1017 - Staff Study - (35.54 SQM)	Office (8)	
B00B - R1019 - General Learning Space - (65.2 SQM) - Teaching Space: 1	Student Space (46)	
B00C - R0002 - Movement - (45.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Staff Study - (24.67 SQM)	Office (6)	
B00C - R0006 - Preparation - Science - (26.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Laboratory L.S. - (87.02 SQM) - Teaching Space: 1	Student Space (59)	
B00C - R0009 - Movement - (36.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Student Canteen - (37.71 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0017 - Food Technology L.S. - (104.8 SQM) - Teaching Space: 1	● Student Space (65)	
B00C - R0019 - Movement - (31 SQM)	Not Applicable	Circulation or storage space.
B00C - R0036 - Staff Study - (21.15 SQM)	● Office (5)	
B00C - R0038 - Movement - (43.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Computer Learning Space - (51.93 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R1004 - Art Learning Space - (78.62 SQM) - Teaching Space: 1	● Student Space (46)	
B00C - R1006 - General Learning Space - (65.2 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R1007 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R1010 - Staff Study - (21.64 SQM)	● Office (5)	
B00C - R1011 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R1012 - General Learning Space - (51.72 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R1013 - General Learning Space - (52.22 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R1015 - Staff Study - (18.66 SQM)	● Office (4)	
B00C - R1022 - Movement - (161.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (51.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Laboratory L.S. - (91.66 SQM) - Teaching Space: 1	● Student Space (59)	
B00D - R0016 - Laboratory L.S. - (93.66 SQM) - Teaching Space: 1	● Student Space (78)	
B00D - R0017 - Preparation - Science - (21.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Staff Study - (24.37 SQM)	● Office (6)	
B00D - R0021 - Movement - (36.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R1007 - General Learning Space - (38.79 SQM) - Teaching Space: 1	● Student Space (34)	
B00D - R1009 - Staff Study - (25.39 SQM)	● Office (6)	
B00D - R1010 - General Learning Space - (65.29 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1011 - General Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (40)	
B00D - R1014 - Movement - (82.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Laboratory L.S. - (96.48 SQM) - Teaching Space: 1	● Student Space (90)	
B00E - R0002 - Preparation - Science - (38.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Laboratory L.S. - (91.51 SQM) - Teaching Space: 1	● Student Space (59)	
B00E - R0004 - General Learning Space - (50.48 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R0008 - Movement - (68.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - General Learning Space - (65.58 SQM) - Teaching Space: 1	● Student Space (65)	
B00E - R1005 - General Learning Space - (64.99 SQM) - Teaching Space: 1	● Student Space (46)	
B00E - R1006 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R1007 - General Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R1008 - General Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (40)	
B00E - R1011 - Movement - (71.47 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (6.06 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (6.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Music Learning Space - (78.45 SQM) - Teaching Space: 1	● Student Space (79)	
B00F - R0012 - General Learning Space - (64.94 SQM) - Teaching Space: 1	● Student Space (64)	
B00G - R0001 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Wood Technology L.S. - (77.85 SQM) - Teaching Space: 1	● Student Space (89)	
B00G - R0015 - Metal Technology L.S. - (72.16 SQM) - Teaching Space: 1	● Student Space (89)	
B00G - R0017 - Metal Technology Bay - (10.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Metal Technology L.S. - (71.6 SQM) - Teaching Space: 1	● Student Space (89)	
B00H - R0001 - General Assistants - (19.09 SQM)	● Office (4)	
B00I - R0001 - Multi-Purpose Space - (458.36 SQM)	● Student Space (212)	
B00I - R0002 - Stage - (96.6 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0005 - Movement - (21.1 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Staff Kitchen - (15.93 SQM)	Office (3)	
B00K - R0001 - Main Entry - (14.92 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Movement - (33.41 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Multi Media Workshop - (49.87 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Tiered Learning Area - (11.1 SQM)	Student Space (5)	
B00K - R0019 - Main Area - (203.97 SQM)	Not Applicable	Circulation or storage space.
B00K - R1004 - Leading Teacher - (16.25 SQM)	Office (4)	
B00K - R1017 - Study Space - (57.97 SQM)	Not Applicable	Circulation or storage space.
B00K - R1018 - Independent Learning Space - (74.21 SQM) - Teaching Space: 1	Student Space (36)	
B00K - R1019 - Seminar - (33.1 SQM)	Office (8)	
B00K - R1022 - Independent Learning Space - (86.99 SQM) - Teaching Space: 1	Student Space (36)	
B00K - R1023 - Movement - (14.85 SQM)	Not Applicable	Circulation or storage space.
B00K - R1026 - Ancillary Staff - (10.2 SQM)	Office (2)	
B00O - R0006 - General Learning Space - (65.26 SQM) - Teaching Space: 1	Student Space (19)	
B00O - R0007 - Fitness Laboratory - (75.74 SQM)	Student Space (24)	
B00Q - R0001 - General Learning Space - (61 SQM) - Teaching Space: 1	Student Space (30)	
B00Q - R0002 - General Learning Space - (60.91 SQM) - Teaching Space: 1	Student Space (30)	
B00Q - R0003 - Movement Studio - (104.25 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0004 - Staff Study - (19.45 SQM)	Office (4)	
B00Q - R0012 - Movement Studio - (130.53 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0015 - Performance Workshop - (31.88 SQM)	Student Space (98)	
OS 601 10672 - OS 601 10672 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (100)	
OS 601 14104 - OS 601 14104 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (88)	