

<b>SCHOOL:</b>	<b>Carlingford High School (8447)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Epping</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Parramatta</b>

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0018 - Deputy Principal Office - (20.76 SQM)	Office (5)	
B00A - R0020 - General Learning Space - (58.37 SQM) - Teaching Space: 1	Student Space (60)	
B00A - R0023 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (59)	
B00A - R0027 - Laboratory L.S. - (88.23 SQM) - Teaching Space: 1	Student Space (48)	
B00A - R0029 - Preparation - Science - (29.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Laboratory L.S. - (83.15 SQM) - Teaching Space: 1	Student Space (67)	
B00A - R0040 - Ancillary Staff - (13.97 SQM)	Office (3)	
B00A - R0041 - Interview/Meeting - (10.81 SQM)	Office (2)	
B00A - R0042 - Clinic - (6.47 SQM)	Office (1)	
B00A - R0043 - Principal Office - (21.7 SQM)	Office (5)	
B00A - R0044 - Public Reception - (46.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Interview/Meeting - (12.5 SQM)	Office (3)	
B00A - R0046 - Administration - Clerical - (55.4 SQM)	Office (13)	
B00A - R0047 - Administration - Clerical - (10.17 SQM)	Office (2)	
B00A - R0048 - Deputy Principal Office - (21.31 SQM)	Office (5)	
B00A - R1003 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (83)	
B00A - R1005 - Interview/Office - Type 1 - (12.96 SQM)	Office (3)	
B00A - R1006 - General Learning Space - (58.21 SQM) - Teaching Space: 1	Student Space (56)	
B00A - R1008 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (59)	
B00A - R1010 - Design L.S. - (66.05 SQM) - Teaching Space: 1	Student Space (83)	
B00A - R1013 - Computer Learning Space - (71.6 SQM) - Teaching Space: 1	Student Space (83)	
B00A - R1017 - General Learning Space - (52.43 SQM) - Teaching Space: 1	Student Space (59)	
B00A - R1030 - Administration - Clerical - (12.43 SQM)	Office (3)	
B00A - R1031 - Interview/Office - Type 1 - (13.36 SQM)	Office (3)	
B00A - R1032 - Commonroom - (74.97 SQM)	Office (18)	
B00A - R1033 - Staff Kitchen - (10.11 SQM)	Office (2)	
B00A - R1034 - Staff Study - (23.21 SQM)	Office (5)	
B00A - R1036 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (59)	
B00A - R1037 - General Learning Space - (52.44 SQM) - Teaching Space: 1	Student Space (59)	
B00B - R0005 - General Learning Space - (51.7 SQM) - Teaching Space: 1	Student Space (77)	
B00B - R0006 - Staff Study - (57.97 SQM)	Office (14)	
B00B - R0007 - Food Technology L.S. - (66.07 SQM) - Teaching Space: 1	Student Space (83)	
B00B - R0010 - Food Technology L.S. - (77.39 SQM) - Teaching Space: 1	Student Space (61)	
B00B - R0020 - Materials Technology L.S. - (85.54 SQM) - Teaching Space: 1	Student Space (89)	
B00B - R0021 - Welding Area - (25.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Materials Technology L.S. - (83.32 SQM) - Teaching Space: 1	Student Space (65)	
B00B - R0024 - Design/Technology L.S. - (67.69 SQM) - Teaching Space: 1	Student Space (77)	
B00B - R0034 - Laboratory L.S. - (64.36 SQM) - Teaching Space: 1	Student Space (70)	
B00B - R0038 - Preparation - (25.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (77)	
B00B - R1009 - Art Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (77)	
B00B - R1011 - Art Learning Space - (71.79 SQM) - Teaching Space: 1	Student Space (84)	
B00B - R1015 - General Learning Space - (52.44 SQM) - Teaching Space: 1	Student Space (77)	
B00B - R1018 - Materials Technology L.S. - (86.44 SQM) - Teaching Space: 1	Student Space (84)	
B00B - R1019 - Workshop - (34.29 SQM)	Student Space (22)	
B00B - R1021 - Materials Technology L.S. - (79.2 SQM) - Teaching Space: 1	Student Space (84)	
B00B - R1025 - Design L.S. - (58.36 SQM) - Teaching Space: 1	Student Space (77)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1040 - Art Learning Space - (60.6 SQM) - Teaching Space: 1	● Student Space (77)	
B00B - R1042 - Staff Study - (23.06 SQM)	● Office (5)	
B00B - R1043 - Staff Study - (44.9 SQM)	● Office (11)	
B00C - R0007 - Student Canteen - (56.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (10.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Movement - (19.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Movement - (12.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - Movement - (12.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (77)	
B00D - R0008 - Laboratory L.S. - (92.59 SQM) - Teaching Space: 1	● Student Space (87)	
B00D - R0015 - General Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (77)	
B00D - R0017 - Leading Teacher - (12.89 SQM)	● Office (3)	
B00D - R0018 - General Learning Space - (58.51 SQM) - Teaching Space: 1	● Student Space (48)	
B00D - R0019 - Laboratory L.S. - (89.74 SQM) - Teaching Space: 1	● Student Space (87)	
B00D - R0022 - Laboratory L.S. - (82.52 SQM) - Teaching Space: 1	● Student Space (94)	
B00D - R0027 - Preparation - Science - (9.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0035 - Staff Study - (50.81 SQM)	● Office (12)	
B00D - R0039 - Preparation - Science - (39.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - General Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (77)	
B00D - R1005 - General Learning Space - (57.93 SQM) - Teaching Space: 1	● Student Space (77)	
B00D - R1006 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (77)	
B00D - R1011 - Computer Room - (12.52 SQM)	● Student Space (11)	
B00D - R1012 - Computer Learning Space - (58.36 SQM) - Teaching Space: 1	● Student Space (77)	
B00D - R1015 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (77)	
B00D - R1017 - Interview/Office - Type 1 - (12.93 SQM)	● Office (3)	
B00D - R1018 - General Learning Space - (57.62 SQM) - Teaching Space: 1	● Student Space (77)	
B00D - R1019 - General Learning Space - (51.41 SQM) - Teaching Space: 1	● Student Space (77)	
B00D - R1020 - General Learning Space - (51.92 SQM) - Teaching Space: 1	● Student Space (77)	
B00D - R1022 - Staff Study - (39.27 SQM)	● Office (9)	
B00D - R1023 - General Learning Space - (58.51 SQM) - Teaching Space: 1	● Student Space (77)	
B00D - R1030 - Staff Study - (73.98 SQM)	● Office (18)	
B00E - R0007 - General Learning Space - (50.71 SQM) - Teaching Space: 1	● Student Space (77)	
B00E - R0008 - General Learning Space - (57.11 SQM) - Teaching Space: 1	● Student Space (77)	
B00E - R0020 - Music Learning Space - (51.79 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R0023 - Leading Teacher - (12.36 SQM)	● Office (3)	
B00E - R0024 - Staff Lounge - (17.24 SQM)	● Office (4)	
B00E - R0031 - Staff Study - (35.45 SQM)	● Office (8)	
B00E - R0036 - Practice/Seminar - (15.14 SQM)	● Student Space (7)	
B00E - R0037 - Practice/Seminar - (15.24 SQM)	● Student Space (7)	
B00E - R0042 - Music Learning Space - (78.45 SQM) - Teaching Space: 1	● Student Space (55)	
B00E - R0043 - Music Learning Space - (61.95 SQM) - Teaching Space: 1	● Student Space (47)	
B00E - R0045 - Performance Workspace - (95.38 SQM) - Teaching Space: 1	● Student Space (65)	
B00E - R0046 - Staff Study - (32.67 SQM)	● Office (8)	
B00E - R0048 - Staff Study - (12.65 SQM)	● Office (3)	
B00E - R0050 - Staff Study - (25.07 SQM)	● Office (6)	
B00E - R1004 - General Learning Space - (50.5 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R1008 - Laboratory L.S. - (88.09 SQM) - Teaching Space: 1	● Student Space (55)	
B00E - R1011 - Preparation - Science - (22.03 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1013 - Laboratory L.S. - (81.05 SQM) - Teaching Space: 1	● Student Space (55)	
B00E - R1017 - General Learning Space - (50.71 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R1019 - Interview/Office - Type 1 - (12.55 SQM)	● Office (3)	
B00E - R1020 - General Learning Space - (57.11 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R1021 - General Learning Space - (51.43 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R1022 - General Learning Space - (51.57 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R1023 - Study Space - (25.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R1024 - General Learning Space - (57.17 SQM) - Teaching Space: 1	● Student Space (38)	
B00F - R0003 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Multi-Purpose Space - (475.63 SQM)	● Student Space (111)	
B00F - R0018 - Staff Kitchen - (12.39 SQM)	● Office (3)	
B00F - R0025 - Movement - (24.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0029 - Stage - (82.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R1003 - Movement - (137.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Senior Study - (13.51 SQM)	● Office (3)	
B00G - R0002 - Seminar - (13.51 SQM)	● Office (3)	
B00G - R0004 - Computer Learning Space - (60.99 SQM) - Teaching Space: 1	● Student Space (54)	
B00G - R0005 - Main Area - (419.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Computer Learning Space - (65.13 SQM) - Teaching Space: 1	● Student Space (113)	
B00G - R0012 - Main Entry - (30.95 SQM)	Not Applicable	Circulation or storage space.
B00G - R9003 - General Assistants - (30.89 SQM)	● Office (7)	
OS 600 11856 - OS 600 11856 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 15835 - OS 600 15835 - Learning Unit - Small - (57 SQM)	● Student Space (67)	
OS 600 18363 - OS 600 18363 - Learning Unit - Small - (57 SQM)	● Student Space (67)	
OS 600 18368 - OS 600 18368 - Learning Unit - Small - (57 SQM)	● Student Space (51)	
OS 600 19760 - OS 600 19760 - Learning Unit - Small - (57 SQM)	● Student Space (51)	
OS 600 19764 - OS 600 19764 - Learning Unit - Small - (57 SQM)	● Student Space (51)	
OS 600 19777 - OS 600 19777 - Learning Unit - Small - (57 SQM)	● Student Space (51)	
OS 600 19779 - OS 600 19779 - Learning Unit - Small - (57 SQM)	● Student Space (51)	