

SCHOOL:	Casino High School (8154)
AMU REGION:	North Coast
STATE ELECTORATE:	Clarence
LOCAL GOVERNMENT AREA:	Richmond Valley

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0005 - Movement - (17.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (325.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (11.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - General Assistants - (16.69 SQM)	Office (4)	
B00B - R0023 - Movement - (8.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Movement - (9.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Student Canteen - (16.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Student Canteen - (41.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Movement - (15.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Student Canteen - (16.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Student Canteen - (49.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0043 - Gymnasium - (76.6 SQM)	Student Space (35)	
B00B - R0048 - Movement - (8.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Interview/Office - Type 1 - (18.74 SQM)	Office (4)	
B00D - R0003 - Leading Teacher - (12.53 SQM)	Office (3)	
B00D - R0005 - Staff Kitchen - (6.14 SQM)	Office (1)	
B00D - R0023 - Public Entry - (14.13 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Movement - (39.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0026 - Interview/Office - Type 1 - (10.4 SQM)	Office (2)	
B00D - R0027 - Administration - Clerical - (73.5 SQM)	Office (18)	
B00D - R0028 - Clinic - Boys - (10.83 SQM)	Office (2)	
B00D - R0029 - Movement - (30.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0031 - Clinic - Girls - (10.91 SQM)	Office (2)	
B00D - R0032 - Leading Teacher - (14.85 SQM)	Office (3)	
B00D - R0035 - Interview/Office - Type 1 - (7.71 SQM)	Office (1)	
B00D - R0036 - Deputy Principal Office - (13.18 SQM)	Office (3)	
B00D - R0043 - Principal Office - (20.96 SQM)	Office (5)	
B00H - R0001 - Staff Study - (25.76 SQM)	Office (6)	
B00H - R0002 - General Learning Space - (66.27 SQM) - Teaching Space: 1	Student Space (36)	
B00H - R0003 - Staff Study - (26.12 SQM)	Office (6)	
B00H - R0004 - Staff Study - (26.05 SQM)	Office (6)	
B00H - R0005 - Computer Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0009 - Staff Study - (18.9 SQM)	Office (4)	
B00L - R0001 - Audio Visual Workroom - (24.81 SQM)	Student Space (11)	
B00L - R0003 - Workroom - (42.57 SQM)	Office (10)	
B00L - R0005 - Movement - (10.7 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Seminar - (11.54 SQM)	Office (2)	
B00L - R0007 - Seminar - (11.54 SQM)	Office (2)	
B00L - R0010 - Seminar - (11.78 SQM)	Office (2)	
B00L - R0011 - Seminar - (12.53 SQM)	Office (3)	
B00L - R0012 - Seminar - (11.67 SQM)	Office (2)	
B00L - R0013 - Main Area - (433.89 SQM)	Not Applicable	Circulation or storage space.
B00L - R0014 - Entry - (9.74 SQM)	Not Applicable	Circulation or storage space.
B00M - R0008 - Music Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (29)	
B00M - R0011 - Materials Learning Space - Type 1 - (66.22 SQM) - Teaching Space: 1	Student Space (36)	
B00M - R0013 - Music Learning Space - (82.75 SQM) - Teaching Space: 1	Student Space (46)	
B00M - R0016 - Stage - (22.02 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0005 - General Learning Space - S/P - (58.31 SQM) - Teaching Space: 1	Student Space (32)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00Q - R0006 - Withdrawal Space - 1hb - (11.87 SQM)	Student Space (5)	
B00Q - R0007 - General Learning Space - S/P - (58.29 SQM) - Teaching Space: 1	Student Space (32)	
B00Q - R0008 - Practical Activities - S - 1hb - (30.99 SQM)	Student Space (14)	
B0A1 - R0001 - Performance Workspace - (105.09 SQM) - Teaching Space: 1	Student Space (58)	
B0A1 - R0003 - Staff Study - (26.2 SQM)	Office (6)	
B0A1 - R0005 - Staff Study - (39.04 SQM)	Office (9)	
B0A1 - R0006 - Art Learning Space - (93.21 SQM) - Teaching Space: 1	Student Space (52)	
B0A1 - R0009 - Laboratory L.S. - (93.2 SQM) - Teaching Space: 1	Student Space (52)	
B0A1 - R0016 - Preparation - (13.8 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R1001 - General Learning Space - (52.84 SQM) - Teaching Space: 1	Student Space (29)	
B0A1 - R1002 - General Learning Space - (52.98 SQM) - Teaching Space: 1	Student Space (29)	
B0A1 - R1003 - General Learning Space - (52.85 SQM) - Teaching Space: 1	Student Space (29)	
B0A1 - R1004 - General Learning Space - (52.77 SQM) - Teaching Space: 1	Student Space (29)	
B0A1 - R1007 - Staff Study - (25.76 SQM)	Office (6)	
B0A1 - R1010 - Workshop - (39.33 SQM)	Student Space (18)	
B0A1 - R1011 - Art Learning Space - (52.84 SQM) - Teaching Space: 1	Student Space (29)	
B0A1 - R1023 - Dark Room - (22.16 SQM)	Office (5)	
B0A2 - R0001 - Laboratory L.S. - (86.59 SQM) - Teaching Space: 1	Student Space (48)	
B0A2 - R0002 - Preparation - (28.16 SQM)	Not Applicable	Circulation or storage space.
B0A2 - R0004 - Laboratory L.S. - (86.75 SQM) - Teaching Space: 1	Student Space (48)	
B0A2 - R0005 - General Learning Space - (52.85 SQM) - Teaching Space: 1	Student Space (29)	
B0A2 - R0007 - General Learning Space - (66.27 SQM) - Teaching Space: 1	Student Space (36)	
B0A2 - R0008 - General Learning Space - (52.77 SQM) - Teaching Space: 1	Student Space (29)	
B0A2 - R1001 - Senior Study - (39.34 SQM)	Office (9)	
B0A2 - R1002 - General Learning Space - (39.42 SQM) - Teaching Space: 1	Student Space (22)	
B0A2 - R1005 - Staff Study - (25.77 SQM)	Office (6)	
B0A2 - R1007 - General Learning Space - (52.55 SQM) - Teaching Space: 1	Student Space (29)	
B0A2 - R1008 - General Learning Space - (52.92 SQM) - Teaching Space: 1	Student Space (29)	
B0A2 - R1009 - General Learning Space - (52.92 SQM) - Teaching Space: 1	Student Space (29)	
B0A2 - R1010 - General Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (29)	
B0A2 - R1011 - General Learning Space - (52.7 SQM) - Teaching Space: 1	Student Space (29)	
B0A2 - R1012 - Staff Study - (22.15 SQM)	Office (5)	
B0A2 - R1013 - General Learning Space - (66.36 SQM) - Teaching Space: 1	Student Space (36)	
B0A2 - R1016 - Computer Learning Space - (66.35 SQM) - Teaching Space: 1	Student Space (36)	
B0A3 - R0001 - Laboratory L.S. - (86.75 SQM) - Teaching Space: 1	Student Space (48)	
B0A3 - R0004 - Laboratory L.S. - (87.04 SQM) - Teaching Space: 1	Student Space (48)	
B0A3 - R0013 - Preparation - Science - (38.09 SQM)	Not Applicable	Circulation or storage space.
B0A3 - R1001 - Staff Study - (18.95 SQM)	Office (4)	
B0A3 - R1002 - General Learning Space - (53.06 SQM) - Teaching Space: 1	Student Space (29)	
B0A3 - R1004 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (29)	
B0A3 - R1005 - General Learning Space - (53.07 SQM) - Teaching Space: 1	Student Space (29)	
B0A3 - R1006 - General Learning Space - (51.67 SQM) - Teaching Space: 1	Student Space (28)	
B0C1 - R0009 - Materials Technology L.S. - (79.26 SQM) - Teaching Space: 1	Student Space (43)	
B0C1 - R0011 - Staff Study - (22.18 SQM)	Office (5)	
B0C1 - R0012 - Materials Technology L.S. - (79.64 SQM) - Teaching Space: 1	Student Space (43)	
B0C1 - R0014 - Design L.S. - (52.18 SQM) - Teaching Space: 1	Student Space (29)	
B0C1 - R0019 - Metal Technology Bay - (142.96 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
BOC2 - R0008 - Food Technology L.S. - (66.42 SQM) - Teaching Space: 1	 Student Space (36)	
BOC2 - R0017 - Kitchen - Type 1 - (125.34 SQM)	 Student Space (58)	
BOC2 - R0018 - Preparation - Materials - (18.27 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R1001 - Materials Technology L.S. - (66.2 SQM) - Teaching Space: 1	 Student Space (36)	
BOC2 - R1005 - Materials Technology L.S. - (66.27 SQM) - Teaching Space: 1	 Student Space (36)	
BOC2 - R1010 - Staff Study - (25.69 SQM)	 Office (6)	
BOJK - R0001 - Administration - Clerical - (13.7 SQM)	 Office (3)	
BOJK - R0002 - Deputy Principal Office - (19.49 SQM)	 Office (4)	
BOJK - R0003 - Leading Teacher - (13.17 SQM)	 Office (3)	
BOJK - R0009 - Movement - (14.48 SQM)	Not Applicable	Circulation or storage space.
BOJK - R0012 - Staff Kitchen - (6.46 SQM)	 Office (1)	
BOJK - R0013 - Commonroom - (121.61 SQM)	 Office (30)	
BMPU - R0001 - Multi-Purpose Space - (457.77 SQM)	 Student Space (212)	
BMPU - R0002 - Stage - (104.38 SQM)	Not Applicable	Circulation or storage space.
BMPU - R0004 - Public Entry - (69.32 SQM)	Not Applicable	Circulation or storage space.
NS 111 13173 - NS 111 13173 - Learning Unit - Double Secondary/Secure - (114 SQM)	 Student Space (52)	
OS 600 16833 - OS 600 16833 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 626 11503 - OS 626 11503 - Double Learning Unit - H/Cap - (171 SQM)	 Student Space (79)	
OS 801 13120 - OS 801 13120 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.