

<b>SCHOOL:</b>	<b>Cecil Hills High School (8273)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Mulgoa</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Liverpool</b>

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Deputy Principal - (16.99 SQM)	Office (4)	
B00A - R0004 - Clinic - Girls - (14.42 SQM)	Office (3)	
B00A - R0005 - Movement - (9.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Pupil Entry - (13.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Administration - Clerical - (44.02 SQM)	Office (11)	
B00A - R0008 - Public Entry - (15.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (31.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (9.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Interview/Office - Type 1 - (13.88 SQM)	Office (3)	
B00A - R0012 - Leading Teacher - (13.83 SQM)	Office (3)	
B00A - R0013 - Duplicating Workroom - (30.24 SQM)	Office (7)	
B00A - R0014 - Deputy Principal - (12.59 SQM)	Office (3)	
B00A - R0015 - Principal Office - (19.92 SQM)	Office (4)	
B00A - R0016 - Ancillary Staff - (21.87 SQM)	Office (5)	
B00A - R0017 - Deputy Principal Office - (16.55 SQM)	Office (4)	
B00A - R0018 - Movement - (22.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Student Canteen - (55.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Multi-Purpose Space - (463.21 SQM)	Student Space (415)	
B00C - R0015 - Movement - (132.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Interview/Office - Type 1 - (12.23 SQM)	Office (3)	
B00D - R0003 - Interview/Office - Type 1 - (12.16 SQM)	Office (3)	
B00D - R0006 - General Learning Space - (47.98 SQM) - Teaching Space: 1	Student Space (91)	
B00D - R0007 - General Learning Space - (48.01 SQM) - Teaching Space: 1	Student Space (91)	
B00D - R0008 - Special Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (91)	
B00D - R0010 - General Assistants - (13.42 SQM)	Office (3)	
B00D - R0013 - General Learning Space - (48 SQM) - Teaching Space: 1	Student Space (91)	
B00D - R0014 - General Learning Space - (47.99 SQM) - Teaching Space: 1	Student Space (91)	
B00D - R0017 - Movement - (330.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Study Space - (16.28 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Study Space - (16.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Movement - (83.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Clerical Office - (12.4 SQM)	Office (3)	
B00D - R1003 - Clerical Office - (12.27 SQM)	Office (3)	
B00D - R1005 - General Learning Space - (46.69 SQM) - Teaching Space: 1	Student Space (91)	
B00D - R1006 - General Learning Space - (47.51 SQM) - Teaching Space: 1	Student Space (91)	
B00D - R1007 - Special Learning Space - (52.2 SQM) - Teaching Space: 1	Student Space (91)	
B00D - R1009 - General Learning Space - (47.45 SQM) - Teaching Space: 1	Student Space (91)	
B00D - R1010 - General Learning Space - (47.8 SQM) - Teaching Space: 1	Student Space (91)	
B00D - R1011 - Serviced Learning Space - (52.2 SQM) - Teaching Space: 1	Student Space (91)	
B00D - R1012 - Serviced Learning Space - (52.28 SQM) - Teaching Space: 1	Student Space (91)	
B00D - R1013 - Study Space - (17.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Study Space - (17.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R1016 - Movement - (254.18 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - General Learning Space - (47.47 SQM) - Teaching Space: 1	Student Space (87)	
B00E - R0002 - General Learning Space - (47.62 SQM) - Teaching Space: 1	Student Space (87)	
B00E - R0003 - Study Space - (17.26 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Study Space - (17.33 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Shared Study Space - (47.69 SQM)	Office (11)	
B00E - R0006 - General Learning Space - (47.7 SQM) - Teaching Space: 1	Student Space (87)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0007 - General Learning Space - (47.7 SQM) - Teaching Space: 1	Student Space (87)	
B00E - R0008 - General Learning Space - (47.7 SQM) - Teaching Space: 1	Student Space (87)	
B00E - R0011 - General Learning Space - (47.48 SQM) - Teaching Space: 1	Student Space (87)	
B00E - R0012 - General Learning Space - (47.56 SQM) - Teaching Space: 1	Student Space (87)	
B00E - R0014 - Movement - (97.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (88.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (54.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Senior Study - (11.68 SQM)	Office (2)	
B00E - R1002 - Senior Study - (11.68 SQM)	Office (2)	
B00E - R1003 - General Learning Space - (71.98 SQM) - Teaching Space: 1	Student Space (114)	
B00E - R1005 - Staff Study - (17.18 SQM)	Office (4)	
B00E - R1007 - General Learning Space - (47.98 SQM) - Teaching Space: 1	Student Space (87)	
B00E - R1008 - General Learning Space - (47.98 SQM) - Teaching Space: 1	Student Space (87)	
B00E - R1009 - Staff Study - (183.95 SQM)	Office (45)	
B00E - R1010 - General Learning Space - (48.93 SQM) - Teaching Space: 1	Student Space (87)	
B00E - R1011 - General Learning Space - (48.84 SQM) - Teaching Space: 1	Student Space (87)	
B00E - R1013 - Movement - (96.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R1016 - Movement - (5.2 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Interview/Office - Type 1 - (21.93 SQM)	Office (5)	
B00F - R0002 - Laboratory L.S. - (98.42 SQM) - Teaching Space: 1	Student Space (45)	
B00F - R0005 - Growing/Breeding - (22.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Preparation - (86.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (18.82 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Movement - (7.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Laboratory L.S. - (97.42 SQM) - Teaching Space: 1	Student Space (45)	
B00F - R0013 - Commonroom - (114.02 SQM)	Office (28)	
B00F - R0017 - Computer Learning Space - (61.67 SQM) - Teaching Space: 1	Student Space (94)	
B00F - R0020 - Laboratory L.S. - (92.23 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R0021 - Laboratory L.S. - (93.14 SQM) - Teaching Space: 1	Student Space (43)	
B00F - R0022 - Laboratory L.S. - (92.94 SQM) - Teaching Space: 1	Student Space (43)	
B00F - R0023 - Laboratory L.S. - (92.67 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R0033 - Movement - (198.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - General Learning Space - (47.61 SQM) - Teaching Space: 1	Student Space (58)	
B00F - R1002 - Study Space - (14.82 SQM)	Not Applicable	Circulation or storage space.
B00F - R1005 - Movement - (90.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R1007 - General Learning Space - (49.67 SQM) - Teaching Space: 1	Student Space (52)	
B00F - R1008 - General Learning Space - (49.59 SQM) - Teaching Space: 1	Student Space (49)	
B00F - R1009 - General Learning Space - (49.61 SQM) - Teaching Space: 1	Student Space (52)	
B00F - R1011 - General Learning Space - (49.29 SQM) - Teaching Space: 1	Student Space (57)	
B00F - R1012 - General Learning Space - (49.84 SQM) - Teaching Space: 1	Student Space (49)	
B00F - R1013 - Seminar - (13.62 SQM)	Office (3)	
B00F - R1014 - Seminar - (13.58 SQM)	Office (3)	
B00F - R1015 - Seminar - (13.62 SQM)	Office (3)	
B00F - R1017 - Workroom - (45.73 SQM)	Office (11)	
B00F - R1018 - Audio Visual Workroom - (35.89 SQM)	Student Space (41)	
B00F - R1020 - Main Area - (417.33 SQM)	Not Applicable	Circulation or storage space.
B00F - R1022 - Entry - (13.84 SQM)	Not Applicable	Circulation or storage space.
B00F - R1023 - Movement - (46.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R1025 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0004 - Stage - (30.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Performance Workspace - (130.37 SQM) - Teaching Space: 1	● Student Space (93)	
B00G - R0012 - Movement - (15.2 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Movement - (15.15 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Practice/Seminar - (25.66 SQM)	● Student Space (11)	
B00H - R0002 - Music Learning Space - (61.58 SQM) - Teaching Space: 1	● Student Space (87)	
B00H - R0005 - Music Learning Space - (78.05 SQM) - Teaching Space: 1	● Student Space (101)	
B00H - R0007 - Art Learning Space - (61.3 SQM) - Teaching Space: 1	● Student Space (101)	
B00H - R0013 - Art Learning Space - (61.37 SQM) - Teaching Space: 1	● Student Space (72)	
B00H - R0014 - Workshop - (51.93 SQM)	● Student Space (52)	
B00H - R0016 - Art Learning Space - (61.38 SQM) - Teaching Space: 1	● Student Space (72)	
B00H - R0017 - Art Learning Space - (61.28 SQM) - Teaching Space: 1	● Student Space (72)	
B00H - R0018 - Darkroom Space - (28.2 SQM)	○ Office (7)	
B00H - R0019 - Movement - (73.22 SQM)	Not Applicable	Circulation or storage space.
B00H - R0020 - Movement - (201.31 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Staff Study - (191.82 SQM)	○ Office (47)	
B00J - R0002 - Staff Kitchen - (5.78 SQM)	○ Office (1)	
B00J - R0008 - Movement - (17.21 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Interview/Office - Type 1 - (12.45 SQM)	○ Office (3)	
B00J - R0012 - Interview/Office - Type 1 - (12.27 SQM)	○ Office (3)	
B00J - R0013 - Movement - (12.95 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Design L.S. - (99.89 SQM) - Teaching Space: 1	● Student Space (119)	
B00K - R0004 - Seminar - (14.23 SQM)	○ Office (3)	
B00K - R0005 - Design L.S. - (76.56 SQM) - Teaching Space: 1	● Student Space (119)	
B00K - R0006 - Design L.S. - (76.38 SQM) - Teaching Space: 1	● Student Space (119)	
B00K - R0009 - Seminar - (14.04 SQM)	○ Office (3)	
B00K - R0010 - Design L.S. - (100.38 SQM) - Teaching Space: 1	● Student Space (140)	
B00K - R0011 - Metal Technology Bay - (35.18 SQM)	Not Applicable	Circulation or storage space.
B00K - R0012 - Welding Area - (7.42 SQM)	Not Applicable	Circulation or storage space.
B00K - R0013 - Materials Technology L.S. - (186.27 SQM) - Teaching Space: 1	● Student Space (181)	
B00K - R0014 - Workshop Area - (57.34 SQM)	● Student Space (26)	
B00K - R0015 - Welding Area - (12.61 SQM)	Not Applicable	Circulation or storage space.
B00K - R0019 - Wood Technology Bay - (35.27 SQM)	Not Applicable	Circulation or storage space.
B00K - R0022 - Food/Research Space - (40.61 SQM)	Not Applicable	Circulation or storage space.
B00K - R0023 - Food Technology L.S. - (76.15 SQM) - Teaching Space: 1	● Student Space (119)	
B00K - R0028 - Food Technology L.S. - (75.89 SQM) - Teaching Space: 1	● Student Space (119)	
B00K - R0029 - Design L.S. - (76.4 SQM) - Teaching Space: 1	● Student Space (119)	
B00K - R0033 - Movement - (317.01 SQM)	Not Applicable	Circulation or storage space.
B00K - R0035 - Movement - (126.15 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Seminar - Type 3 - (9.18 SQM)	○ Office (2)	
B00L - R0006 - Seminar - Type 3 - (9.21 SQM)	○ Office (2)	
B00L - R0007 - General Learning Space - S/P - (62.4 SQM) - Teaching Space: 1	● Student Space (85)	
B00L - R0008 - General Learning Space - S/P - (64.97 SQM) - Teaching Space: 1	● Student Space (61)	
B00L - R0009 - Practical Activity Area - (91.05 SQM)	● Student Space (61)	
B00L - R0014 - General Learning Space - S/P - (63.14 SQM) - Teaching Space: 1	● Student Space (61)	
B00L - R0016 - Seminar - Type 3 - (9.82 SQM)	○ Office (2)	
B00L - R0017 - Movement - (112.58 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Movement - (9.26 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Practical Activity Area - (19.4 SQM)	● Student Space (60)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R0004 - Special Learning Space - (59.22 SQM) - Teaching Space: 1	 Student Space (40)	
B00M - R0005 - Study Space - (11.36 SQM)	Not Applicable	Circulation or storage space.
B00M - R0006 - Special Learning Space - (59.21 SQM) - Teaching Space: 1	 Student Space (40)	
B00M - R0008 - Practical Activity Area - (19.41 SQM)	 Student Space (60)	
OS 510 12993 - OS 510 12993 - Staff Common Room - (114 SQM)	 Office (28)	
OS 600 10645 - OS 600 10645 - Learning Unit - Small - (57 SQM)	 Student Space (87)	
OS 600 10858 - OS 600 10858 - Learning Unit - Small - (57 SQM)	 Student Space (87)	
OS 600 10943 - OS 600 10943 - Learning Unit - Small - (57 SQM)	 Student Space (81)	
OS 600 12778 - OS 600 12778 - Learning Unit - Small - (57 SQM)	 Student Space (81)	
OS 600 13037 - OS 600 13037 - Learning Unit - Small - (57 SQM)	 Student Space (87)	
OS 600 15843 - OS 600 15843 - Learning Unit - Small - (57 SQM)	 Student Space (81)	
OS 600 17818 - OS 600 17818 - Learning Unit - Small - (57 SQM)	 Student Space (76)	
OS 600 18366 - OS 600 18366 - Learning Unit - Small - (57 SQM)	 Student Space (87)	
OS 601 14450 - OS 601 14450 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (94)	
OS 601 14824 - OS 601 14824 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (94)	
OS 601 15227 - OS 601 15227 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (94)	
OS 601 16061 - OS 601 16061 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (94)	
OS 601 19732 - OS 601 19732 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (101)	