

<b>SCHOOL:</b>	<b>Chatham High School (8414)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Myall Lakes</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Mid-Coast</b>

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Tiered Learning Area - (64.87 SQM)	● Student Space (37)	
B00A - R0005 - Ancillary Staff - (22.39 SQM)	● Office (5)	
B00A - R0006 - Principal Office - (19.06 SQM)	● Office (4)	
B00A - R0010 - Staff Study - (13 SQM)	● Office (3)	
B00A - R0012 - Deputy Principal Office - (13.06 SQM)	● Office (3)	
B00A - R0013 - Administration - Clerical - (12.11 SQM)	● Office (3)	
B00A - R0014 - Duplicating Workroom - (26.79 SQM)	● Office (6)	
B00A - R0016 - Administration - Clerical - (42.55 SQM)	● Office (10)	
B00A - R0017 - Movement - (125.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Clinic - Girls - (16.28 SQM)	● Office (4)	
B00A - R0021 - Clinic - Boys - (16.28 SQM)	● Office (4)	
B00A - R0022 - Deputy Principal Office - (16.27 SQM)	● Office (4)	
B00A - R0023 - Interview/Office - Type 1 - (11.67 SQM)	● Office (2)	
B00A - R0024 - Special Learning Space - (43.53 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0025 - Movement - (73.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Staff Study - (42.76 SQM)	● Office (10)	
B00A - R1005 - General Learning Space - (38.58 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1008 - Interview/Office - Type 1 - (13.39 SQM)	● Office (3)	
B00A - R1009 - General Learning Space - (49.55 SQM) - Teaching Space: 1	● Student Space (47)	
B00A - R1010 - General Learning Space - (49.55 SQM) - Teaching Space: 1	● Student Space (56)	
B00A - R1011 - Movement - (172.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - General Learning Space - (49.55 SQM) - Teaching Space: 1	● Student Space (56)	
B00A - R1017 - General Learning Space - (38.86 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1018 - General Learning Space - (49.41 SQM) - Teaching Space: 1	● Student Space (47)	
B00A - R1019 - General Learning Space - (42.76 SQM) - Teaching Space: 1	● Student Space (47)	
B00A - R9001 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R9004 - Entry - (11.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Darkroom Space - (6.3 SQM)	● Office (1)	
B00B - R0006 - Art Learning Space - (62.63 SQM) - Teaching Space: 1	● Student Space (38)	
B00B - R0007 - Workshop - (61.39 SQM)	● Student Space (37)	
B00B - R0008 - Art Learning Space - (62.83 SQM) - Teaching Space: 1	● Student Space (47)	
B00B - R0010 - Art Learning Space - (62.73 SQM) - Teaching Space: 1	● Student Space (47)	
B00B - R0011 - Movement - (17.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Staff Study - (22.45 SQM)	● Office (5)	
B00B - R0016 - Art Learning Space - (62.77 SQM) - Teaching Space: 1	● Student Space (65)	
B00B - R0017 - Movement - (128.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Computer Room - (33.47 SQM)	● Student Space (19)	
B00B - R0021 - Dark Room - (9.79 SQM)	● Office (2)	
B00B - R0023 - Dark Room - (13.44 SQM)	● Office (3)	
B00B - R1007 - Music Learning Space - (61.85 SQM) - Teaching Space: 1	● Student Space (34)	
B00B - R1008 - Practice/Seminar - (28.03 SQM)	● Student Space (74)	
B00B - R1009 - Movement - (109.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Music Learning Space - (109.26 SQM) - Teaching Space: 1	● Student Space (84)	
B00C - R0001 - Audio Visual Workroom - (34.36 SQM)	● Student Space (23)	
B00C - R0003 - Entry - (14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Seminar - (13.32 SQM)	● Office (3)	
B00C - R0005 - Seminar - (13.36 SQM)	● Office (3)	
B00C - R0006 - Main Area - (445.14 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0010 - Workroom - (44.85 SQM)	Office (11)	
B00D - R0005 - General Learning Space - (51.04 SQM) - Teaching Space: 1	Student Space (47)	
B00D - R0009 - General Learning Space - (45.42 SQM) - Teaching Space: 1	Student Space (75)	
B00D - R0010 - Laboratory L.S. - (90.11 SQM) - Teaching Space: 1	Student Space (93)	
B00D - R0011 - Preparation - (25.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Laboratory L.S. - (89.68 SQM) - Teaching Space: 1	Student Space (112)	
B00D - R0021 - Computer Learning Space - (64.65 SQM) - Teaching Space: 1	Student Space (84)	
B00D - R0024 - Staff Study - (12.55 SQM)	Office (3)	
B00D - R0025 - Staff Study - (45.13 SQM)	Office (11)	
B00D - R0026 - Laboratory L.S. - (89.9 SQM) - Teaching Space: 1	Student Space (84)	
B00D - R0027 - Preparation - (38.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0028 - Laboratory L.S. - (90.4 SQM) - Teaching Space: 1	Student Space (84)	
B00D - R0030 - Movement - (257.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - General Learning Space - (51.4 SQM) - Teaching Space: 1	Student Space (47)	
B00D - R1003 - General Learning Space - (50.38 SQM) - Teaching Space: 1	Student Space (47)	
B00D - R1006 - General Learning Space - (58.03 SQM) - Teaching Space: 1	Student Space (38)	
B00D - R1008 - General Learning Space - (51.47 SQM) - Teaching Space: 1	Student Space (56)	
B00D - R1009 - Staff Study - (77.42 SQM)	Office (19)	
B00D - R1010 - General Learning Space - (38.31 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1011 - General Learning Space - (45.54 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1013 - General Learning Space - (51.54 SQM) - Teaching Space: 1	Student Space (47)	
B00D - R1020 - General Learning Space - (57.81 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R1023 - Staff Study - (18.76 SQM)	Office (4)	
B00D - R1024 - Interview/Office - Type 1 - (12.33 SQM)	Office (3)	
B00D - R1025 - General Learning Space - (51.19 SQM) - Teaching Space: 1	Student Space (56)	
B00D - R1026 - General Learning Space - (57.82 SQM) - Teaching Space: 1	Student Space (56)	
B00D - R1027 - Movement - (260.39 SQM)	Not Applicable	Circulation or storage space.
B00D - R1028 - General Learning Space - (63.94 SQM) - Teaching Space: 1	Student Space (65)	
B00D - R1029 - Senior Seminar - (36.45 SQM)	Office (9)	
B00D - R1030 - General Learning Space - (52.11 SQM) - Teaching Space: 1	Student Space (47)	
B00F - R0002 - Materials Technology L.S. - (103.05 SQM) - Teaching Space: 1	Student Space (75)	
B00F - R0003 - Materials Technology L.S. - (82.21 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R0008 - Movement - (128.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Staff Study - (24.14 SQM)	Office (6)	
B00F - R0010 - Design L.S. - (53.36 SQM) - Teaching Space: 1	Student Space (52)	
B00F - R0013 - Design L.S. - (59.61 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0014 - Interview/Office - Type 1 - (9.25 SQM)	Office (2)	
B00F - R0017 - Design L.S. - (52.25 SQM) - Teaching Space: 1	Student Space (56)	
B00F - R0020 - Materials Technology L.S. - (73 SQM) - Teaching Space: 1	Student Space (38)	
B00F - R0021 - Materials Technology L.S. - (66.75 SQM) - Teaching Space: 1	Student Space (65)	
B00F - R0022 - Welding Area - (12.62 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (365.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Student Canteen - (56.15 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Entry - (14.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Staff Study - (18.53 SQM)	Office (4)	
B00H - R0007 - Multi-Purpose Space - (475.21 SQM)	Student Space (220)	
B00H - R0013 - General Assistants - (13.82 SQM)	Office (3)	
B00H - R0016 - Entry - (12.85 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0018 - Stage - (106.48 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Special Learning Space - (59.15 SQM) - Teaching Space: 1	● Student Space (84)	
B00I - R0002 - Movement - (182.76 SQM)	Not Applicable	Circulation or storage space.
B00I - R0011 - Special Learning Space - (62.3 SQM) - Teaching Space: 1	● Student Space (56)	
B00I - R0012 - Kitchen - Type 1 - (59.06 SQM)	● Student Space (74)	
B00I - R0013 - Special Learning Space - (60.05 SQM) - Teaching Space: 1	● Student Space (75)	
B00I - R0019 - Interview/Office - Type 1 - (16.02 SQM)	○ Office (4)	
B00I - R0020 - Staff Study - (21.69 SQM)	○ Office (5)	
B00I - R0023 - Special Learning Space - (52.85 SQM) - Teaching Space: 1	● Student Space (75)	
B00I - R0024 - Special Learning Space - (52.92 SQM) - Teaching Space: 1	● Student Space (75)	
B00K - R0001 - Performance Workspace - (94.21 SQM) - Teaching Space: 1	● Student Space (52)	
B00N - R0003 - General Assistants - (16.98 SQM)	○ Office (4)	
B00P - R0001 - Computer Learning Space - (91.7 SQM) - Teaching Space: 1	● Student Space (38)	
B00P - R0002 - Seminar - Type 2 - (18.72 SQM)	○ Office (4)	
B00Q - R0001 - General Learning Space - (60.24 SQM) - Teaching Space: 1	● Student Space (38)	
B00Q - R0002 - General Learning Space - (60.1 SQM) - Teaching Space: 1	● Student Space (38)	
B00Q - R0003 - Kitchen - Type 1 - (100.85 SQM)	● Student Space (46)	
B00Q - R0006 - Preparation - (27.94 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0008 - Movement - (24.24 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0012 - Seminar - Type 2 - (20.84 SQM)	○ Office (5)	
B00Q - R0014 - General Learning Space - Type 6 - (59.11 SQM) - Teaching Space: 1	● Student Space (32)	
B00Q - R0015 - General Learning Space - Type 7 - (59.89 SQM) - Teaching Space: 1	● Student Space (47)	
B00Q - R0016 - Kitchen - Type 2 - (109.1 SQM)	● Student Space (46)	
B00Q - R1001 - Preparation - (46.13 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1003 - General Learning Space - Type 3 - (61.93 SQM) - Teaching Space: 1	● Student Space (34)	
B00Q - R1004 - General Learning Space - Type 2 - (65.2 SQM) - Teaching Space: 1	● Student Space (65)	
B00Q - R1005 - Science Laboratory - (111.53 SQM)	● Student Space (51)	
B00Q - R1006 - Staff Study - (114.59 SQM)	○ Office (28)	
B00Q - R1007 - Seminar - (20.42 SQM)	○ Office (5)	
B00Q - R1008 - Movement - (9.53 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1009 - Movement - (12.49 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1015 - Staff Lounge - (130.84 SQM)	○ Office (32)	