

SCHOOL:	Chifley College Senior Campus (8473)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Mount Druitt
LOCAL GOVERNMENT AREA:	Blacktown

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
BOCA - R0002 - Interview/Meeting - (12.82 SQM)	Office (3)	
BOCA - R0003 - Interview/Meeting - (12.82 SQM)	Office (3)	
BOCA - R0005 - Interview/Office - Type 1 - (12.77 SQM)	Office (3)	
BOCA - R0006 - Interview/Office - Type 1 - (12.88 SQM)	Office (3)	
BOCA - R0007 - Interview/Office - Type 1 - (12.88 SQM)	Office (3)	
BOCA - R0008 - Deputy Principal Office - (12.88 SQM)	Office (3)	
BOCA - R0009 - Deputy Principal Office - (18.99 SQM)	Office (4)	
BOCA - R0011 - Commonroom - (39.41 SQM)	Office (9)	
BOCA - R0014 - Principal Office - (20.63 SQM)	Office (5)	
BOCA - R0016 - Administration - Executive - (16.8 SQM)	Office (4)	
BOCA - R0018 - Administration - Clerical - (20.04 SQM)	Office (5)	
BOCA - R0022 - Clinic - Boys - (12.84 SQM)	Office (3)	
BOCA - R0025 - Clinic - Girls - (12.57 SQM)	Office (3)	
BOCA - R0026 - Visitors Office - (11.83 SQM)	Office (2)	
BOCA - R0027 - Student Reception - (100.32 SQM)	Not Applicable	Circulation or storage space.
BOCA - R0028 - Administration - Clerical - (110.13 SQM)	Office (27)	
BOCA - R0029 - Tea Room - (5.13 SQM)	Not Applicable	Circulation or storage space.
BOCA - R0031 - Public Reception - (62.94 SQM)	Not Applicable	Circulation or storage space.
BOCB - R0002 - Computer Learning Space - (66.12 SQM) - Teaching Space: 1	Student Space (28)	
BOCB - R0005 - Seminar - Type 3 - (12.77 SQM)	Office (3)	
BOCB - R0006 - Seminar - Type 3 - (12.77 SQM)	Office (3)	
BOCB - R0007 - Seminar - Type 3 - (12.95 SQM)	Office (3)	
BOCB - R0013 - Main Entry - (31.64 SQM)	Not Applicable	Circulation or storage space.
BOCB - R0020 - Main Area - (296.41 SQM)	Not Applicable	Circulation or storage space.
BOCB - R0021 - General Learning Space - (59.42 SQM) - Teaching Space: 1	Student Space (19)	
BOCB - R1001 - General Learning Space - Type 2 - (64.36 SQM) - Teaching Space: 1	Student Space (38)	
BOCB - R1002 - Movement - (29.15 SQM)	Not Applicable	Circulation or storage space.
BOCB - R1004 - General Learning Space - Type 2 - (65.67 SQM) - Teaching Space: 1	Student Space (56)	
BOCB - R1005 - General Learning Space - Type 1 - (58.85 SQM) - Teaching Space: 1	Student Space (28)	
BOCB - R1007 - Seminar - Type 1 - (24.42 SQM)	Office (6)	
BOCB - R1008 - General Learning Space - Type 1 - (59.57 SQM) - Teaching Space: 1	Student Space (76)	
BOCB - R1009 - General Learning Space - Type 1 - (59.57 SQM) - Teaching Space: 1	Student Space (50)	
BOCB - R1013 - Movement - (29.21 SQM)	Not Applicable	Circulation or storage space.
BOCB - R1014 - General Learning Space - Type 2 - (64.44 SQM) - Teaching Space: 1	Student Space (38)	
BOCB - R1015 - Shared Learning Space - (115.68 SQM)	Student Space (37)	
BOCC - R0001 - General Learning Space - Type 3 - (59.2 SQM) - Teaching Space: 1	Student Space (31)	
BOCC - R0002 - General Learning Space - Type 3 - (59.88 SQM) - Teaching Space: 1	Student Space (31)	
BOCC - R0003 - General Learning Space - Type 3 - (60.04 SQM) - Teaching Space: 1	Student Space (31)	
BOCC - R0004 - General Learning Space - Type 3 - (59.04 SQM) - Teaching Space: 1	Student Space (31)	
BOCC - R0005 - Science Laboratory - (100.12 SQM)	Student Space (56)	
BOCC - R0012 - Preparation - Science - (50.06 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0018 - Science Laboratory - (100.32 SQM)	Student Space (46)	
BOCC - R0022 - General Learning Space - (39.06 SQM) - Teaching Space: 1	Student Space (94)	
BOCC - R1001 - Staff Study - (146.31 SQM)	Office (36)	
BOCC - R1003 - Interview/Meeting - (15.35 SQM)	Office (3)	
BOCC - R1004 - Interview/Meeting - (14.4 SQM)	Office (3)	
BOCC - R1013 - Interview/Meeting - (14.79 SQM)	Office (3)	
BOCC - R1014 - Interview/Meeting - (14.79 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOCC - R1018 - Movement - (95.17 SQM)	Not Applicable	Circulation or storage space.
BOCC - R1019 - Staff Study - (195.71 SQM)	Office (48)	
BOCC - R1020 - Staff Lounge - (89.67 SQM)	Office (22)	
BOCD - R0001 - General Learning Space - Type 1 - (59.64 SQM) - Teaching Space: 1	Student Space (65)	
BOCD - R0002 - General Learning Space - Type 1 - (59.13 SQM) - Teaching Space: 1	Student Space (27)	
BOCD - R0003 - General Learning Space - Type 1 - (59.49 SQM) - Teaching Space: 1	Student Space (65)	
BOCD - R0004 - General Learning Space - Type 1 - (58.73 SQM) - Teaching Space: 1	Student Space (65)	
BOCD - R0005 - General Learning Space - Type 2 - (65.99 SQM) - Teaching Space: 1	Student Space (33)	
BOCD - R0006 - General Learning Space - Type 2 - (65.38 SQM) - Teaching Space: 1	Student Space (33)	
BOCD - R0007 - Seminar - Type 1 - (29.03 SQM)	Office (7)	
BOCD - R0011 - Movement - (30.21 SQM)	Not Applicable	Circulation or storage space.
BOCD - R0016 - Shared Learning Space - (117.01 SQM)	Student Space (56)	
BOCD - R1003 - Movement - (27.66 SQM)	Not Applicable	Circulation or storage space.
BOCD - R1006 - Seminar - Type 1 - (28.95 SQM)	Office (7)	
BOCD - R1007 - General Learning Space - Type 1 - (59.58 SQM) - Teaching Space: 1	Student Space (65)	
BOCD - R1008 - General Learning Space - Type 1 - (59.24 SQM) - Teaching Space: 1	Student Space (49)	
BOCD - R1009 - General Learning Space - Type 1 - (59.58 SQM) - Teaching Space: 1	Student Space (65)	
BOCD - R1010 - General Learning Space - Type 1 - (58.95 SQM) - Teaching Space: 1	Student Space (65)	
BOCD - R1011 - General Learning Space - Type 2 - (64.44 SQM) - Teaching Space: 1	Student Space (65)	
BOCD - R1012 - General Learning Space - Type 2 - (64.27 SQM) - Teaching Space: 1	Student Space (62)	
BOCD - R1017 - Shared Learning Space - (112.24 SQM)	Student Space (37)	
BOCD - R1018 - Movement - (20.63 SQM)	Not Applicable	Circulation or storage space.
BOCE - R0001 - General Learning Space - Type 1 - (58.79 SQM) - Teaching Space: 1	Student Space (43)	
BOCE - R0002 - General Learning Space - Type 1 - (58.58 SQM) - Teaching Space: 1	Student Space (43)	
BOCE - R0015 - Fitness Laboratory - (100.2 SQM)	Student Space (37)	
BOCE - R0017 - Practice/Seminar - (19.44 SQM)	Student Space (9)	
BOCE - R1002 - Practice/Seminar - (18.86 SQM)	Student Space (9)	
BOCE - R1003 - General Learning Space - Type 7 - (58.16 SQM) - Teaching Space: 1	Student Space (37)	
BOCE - R1004 - General Learning Space - Type 6 - (57.95 SQM) - Teaching Space: 1	Student Space (37)	
BOCE - R1005 - General Learning Space - Type 1 - (62.57 SQM) - Teaching Space: 1	Student Space (28)	
BOCE - R1006 - General Learning Space - Type 1 - (62.48 SQM) - Teaching Space: 1	Student Space (37)	
BOCE - R1008 - Seminar - Type 2 - (19.78 SQM)	Office (4)	
BOCE - R1012 - Preparation - Materials - (28.95 SQM)	Not Applicable	Circulation or storage space.
BOCE - R1013 - Kitchen - Type 1 - (112.76 SQM)	Student Space (46)	
BOCE - R1016 - Performance Workshop - (98.98 SQM)	Student Space (28)	
BOCF - R0001 - General Learning Space - Type 4 - (59.99 SQM) - Teaching Space: 1	Student Space (19)	
BOCF - R0002 - General Learning Space - Type 5 - (59.9 SQM) - Teaching Space: 1	Student Space (34)	
BOCF - R0003 - General Learning Space - Type 8 - (59.82 SQM) - Teaching Space: 1	Student Space (51)	
BOCF - R0004 - General Learning Space - Type 9 - (57.58 SQM) - Teaching Space: 1	Student Space (51)	
BOCF - R0008 - Materials Workshop - Type 2 - (112.56 SQM)	Student Space (46)	
BOCF - R0011 - Wood Technology Bay - (5.89 SQM)	Not Applicable	Circulation or storage space.
BOCF - R0013 - Visual Arts Workshop - (104.89 SQM)	Student Space (46)	
BOCF - R0014 - Outdoor Workshop - (89.25 SQM)	Not Applicable	Circulation or storage space.
BOCF - R0016 - Dark Room - (28.67 SQM)	Office (7)	
BOCF - R0021 - Welding/Hot Metals Area - (11.22 SQM)	Not Applicable	Circulation or storage space.
BOCG - R0003 - Multi-Purpose Space - (619.12 SQM)	Student Space (56)	
BOCG - R0011 - Stage - (94.56 SQM)	Not Applicable	Circulation or storage space.
BOCH - R0002 - Movement - (118.5 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
BOCH - R0003 - Student Canteen - (52.8 SQM)	Not Applicable	Circulation or storage space.
BOCJ - R0003 - Tiered Learning Area - (100.04 SQM)	● Student Space (46)	
BOCK - R0001 - Movement - (41.52 SQM)	Not Applicable	Circulation or storage space.
BOCK - R0002 - Workshop Area - (154.21 SQM)	● Student Space (71)	
OS 602 10288 - OS 602 10288 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (74)	