

| | |
|-------------------------------|-------------------------------------|
| SCHOOL: | Coonamble High School (8451) |
| AMU REGION: | North Western NSW |
| STATE ELECTORATE: | Barwon |
| LOCAL GOVERNMENT AREA: | Coonamble |

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0002 - Staff Study - (12.98 SQM) | Office (3) | |
| B00A - R0005 - Staff Study - (47.21 SQM) | Office (11) | |
| B00A - R0006 - Staff Study - (47.21 SQM) | Office (11) | |
| B00A - R0009 - Commonroom - (62.37 SQM) | Office (15) | |
| B00A - R0014 - Interview/Meeting - (33.17 SQM) | Office (8) | |
| B00A - R0015 - Movement - (68.24 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1002 - General Learning Space - (47.75 SQM) - Teaching Space: 1 | Student Space (29) | |
| B00A - R1003 - General Learning Space - (47.87 SQM) - Teaching Space: 1 | Student Space (29) | |
| B00A - R1004 - General Learning Space - (49.18 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00A - R1005 - General Learning Space - (49.05 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00A - R1007 - Staff Study - (14.6 SQM) | Office (3) | |
| B00A - R1011 - Movement - (45.41 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0009 - Deputy Principal Office - (13.57 SQM) | Office (3) | |
| B00B - R0011 - Principal Office - (20.99 SQM) | Office (5) | |
| B00B - R0017 - Laboratory L.S. - (92.38 SQM) - Teaching Space: 1 | Student Space (41) | |
| B00B - R0021 - Movement - (169.44 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0024 - Interview/Office - Type 2 - (16.09 SQM) | Office (4) | |
| B00B - R0025 - Staff Kitchen - (8.86 SQM) | Office (2) | |
| B00B - R0026 - Movement - (24.51 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0029 - Movement - (7.64 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0030 - Administration - Clerical - (17.72 SQM) | Office (4) | |
| B00B - R0031 - Deputy Principal Office - (19.22 SQM) | Office (4) | |
| B00B - R0032 - Student Reception - (9.75 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0033 - Movement - (45.89 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0034 - Interview/Meeting - (8.17 SQM) | Office (2) | |
| B00B - R0035 - Interview/Meeting - (7.87 SQM) | Office (1) | |
| B00B - R0036 - Interview/Meeting - (10.22 SQM) | Office (2) | |
| B00B - R0037 - Interview/Meeting - (9.88 SQM) | Office (2) | |
| B00B - R0038 - Administration - Executive - (29.48 SQM) | Office (7) | |
| B00B - R0039 - Movement - (19.98 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0042 - Interview/Office - Type 1 - (8.07 SQM) | Office (2) | |
| B00B - R0043 - Principal Office - (18.81 SQM) | Office (4) | |
| B00B - R0044 - Public Entry - (16.74 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0045 - Administration - Clerical - (29.75 SQM) | Office (7) | |
| B00B - R0046 - Pupil Entry - (6.3 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0047 - Deputy Principal Office - (11.77 SQM) | Office (2) | |
| B00B - R0048 - Study Space - (9.29 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0049 - Movement - (16.97 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0050 - Interview/Meeting - (21.3 SQM) | Office (5) | |
| B00B - R0051 - Interview/Office - Type 1 - (8.97 SQM) | Office (2) | |
| B00B - R0053 - Deputy Principal Office - (11.29 SQM) | Office (2) | |
| B00B - R0056 - Interview/Office - Type 1 - (6.59 SQM) | Office (1) | |
| B00B - R1002 - General Learning Space - (59.83 SQM) - Teaching Space: 1 | Student Space (32) | |
| B00B - R1005 - Staff Study - (52.21 SQM) | Office (13) | |
| B00B - R1006 - General Learning Space - (52.29 SQM) - Teaching Space: 1 | Student Space (29) | |
| B00B - R1009 - General Learning Space - (65.5 SQM) - Teaching Space: 1 | Student Space (36) | |
| B00B - R1012 - Computer Learning Space - (52.14 SQM) - Teaching Space: 1 | Student Space (29) | |
| B00B - R1013 - Staff Study - (25.56 SQM) | Office (6) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00B - R1018 - Movement - (164.15 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0001 - Special Learning Space - (53.97 SQM) - Teaching Space: 1 | ● Student Space (56) | |
| B00D - R0002 - Special Learning Space - (53.68 SQM) - Teaching Space: 1 | ● Student Space (56) | |
| B00D - R0003 - Staff Kitchen - (12.9 SQM) | ● Office (3) | |
| B00D - R0006 - General Learning Space - (53.09 SQM) - Teaching Space: 1 | ● Student Space (56) | |
| B00D - R0007 - Staff Study - (18.72 SQM) | ● Office (4) | |
| B00E - R0001 - Staff Study - (15.8 SQM) | ● Office (3) | |
| B00E - R0003 - Materials Technology L.S. - (89.33 SQM) - Teaching Space: 1 | ● Student Space (143) | |
| B00E - R0009 - Food Technology L.S. - (106.78 SQM) - Teaching Space: 1 | ● Student Space (161) | |
| B00E - R0011 - Preparation - Materials - (18.22 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0001 - General Learning Space - (69.42 SQM) - Teaching Space: 1 | ● Student Space (104) | |
| B00F - R0004 - Art Learning Space - (65.72 SQM) - Teaching Space: 1 | ● Student Space (36) | |
| B00F - R0005 - Workshop - (44.85 SQM) | ● Student Space (20) | |
| B00F - R0007 - General Learning Space - (65.81 SQM) - Teaching Space: 1 | ● Student Space (36) | |
| B00F - R0009 - Design L.S. - (87.13 SQM) - Teaching Space: 1 | ● Student Space (48) | |
| B00F - R0012 - Materials Technology L.S. - (115.77 SQM) - Teaching Space: 1 | ● Student Space (39) | |
| B00F - R0016 - Materials Technology L.S. - (107.29 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B00F - R0019 - Staff Study - (26.06 SQM) | ● Office (6) | |
| B00F - R0021 - Darkroom Space - (27.54 SQM) | ● Office (6) | |
| B00F - R0026 - Metal Technology Bay - (65.58 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0005 - Staff Study - (11.02 SQM) | ● Office (2) | |
| B00G - R0006 - Movement - (308.54 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0007 - Student Canteen - (38.86 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0010 - Movement - (6.17 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0001 - Multi-Purpose Space - (449.9 SQM) | ● Student Space (208) | |
| B00H - R0006 - Movement - (17.75 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0012 - Staff Kitchen - (11.94 SQM) | ● Office (2) | |
| B00H - R0020 - Stage - (85.18 SQM) | Not Applicable | Circulation or storage space. |
| B00I - R0003 - Music Learning Space - (53.23 SQM) | ● Student Space (24) | |
| B00J - R0001 - Movement - (40.15 SQM) | Not Applicable | Circulation or storage space. |
| B00M - R0001 - General Learning Space - (60.03 SQM) - Teaching Space: 1 | ● Student Space (38) | |
| B00M - R0002 - Science Laboratory - (60.03 SQM) | ● Student Space (56) | |
| B00M - R0003 - Preparation - (30.33 SQM) | Not Applicable | Circulation or storage space. |
| B00M - R0004 - Staff Study - (21.04 SQM) | ● Office (5) | |
| B00M - R0005 - Seminar - Type 2 - (21.04 SQM) | ● Office (5) | |
| B00M - R0008 - Movement - (6.18 SQM) | Not Applicable | Circulation or storage space. |
| B00N - R0001 - Welding/Hot Metals Area - (87.15 SQM) | Not Applicable | Circulation or storage space. |
| B00O - R0001 - Gymnasium - (104.84 SQM) | ● Student Space (48) | |
| B00O - R0002 - Outdoor Learning Area - (106.46 SQM) | Not Applicable | Circulation or storage space. |
| BOCA - R0001 - Laboratory L.S. - (90.24 SQM) - Teaching Space: 1 | ● Student Space (181) | |
| BOCA - R0005 - Movement - (22.17 SQM) | Not Applicable | Circulation or storage space. |
| BOCB - R0001 - Main Area - (180.01 SQM) | Not Applicable | Circulation or storage space. |
| BOCB - R0003 - Seminar - (8.05 SQM) | ● Office (2) | |
| BOCB - R0004 - Seminar - (8.11 SQM) | ● Office (2) | |
| BOCB - R0005 - Study Space - (34.52 SQM) | Not Applicable | Circulation or storage space. |
| BOCB - R0006 - Audio Visual Workroom - (8.79 SQM) | ● Student Space (4) | |
| BOCB - R0008 - Seminar - (24.75 SQM) | ● Office (6) | |
| BOCC - R0002 - Senior Study - (12.98 SQM) | ● Office (3) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|---------|
| BOCC - R0003 - Interview/Office - Type 1 - (12.7 SQM) |  Office (3) | |
| BOCC - R0004 - Special Learning Space - (62.52 SQM) - Teaching Space: 1 |  Student Space (153) | |
| BOCC - R0005 - Staff Study - (22.22 SQM) |  Office (5) | |
| BOCC - R0013 - Kitchen - Type 1 - (14.91 SQM) |  Student Space (6) | |
| OS 523 13832 - OS 523 13832 - Staff Study With Toilets - (76 SQM) |  Office (19) | |
| OS 601 11433 - OS 601 11433 - Learning Unit - Standard/Withdrawal - (76 SQM) |  Student Space (35) | |
| OS 601 12711 - OS 601 12711 - Learning Unit - Standard/Withdrawal - (76 SQM) |  Student Space (35) | |
| OS 601 14284 - OS 601 14284 - Learning Unit - Standard/Withdrawal - (76 SQM) |  Student Space (35) | |
| OS 601 15714 - OS 601 15714 - Learning Unit - Standard/Withdrawal - (76 SQM) |  Student Space (35) | |
| OS 601 16062 - OS 601 16062 - Learning Unit - Standard/Withdrawal - (76 SQM) |  Student Space (35) | |