


SCHOOL:	Copmanhurst Public School (1642)
AMU REGION:	North Coast
STATE ELECTORATE:	Clarence
LOCAL GOVERNMENT AREA:	Clarence Valley



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Special Programs Room - (15.59 SQM)	 Student Space (7)	
B00A - R0008 - Movement - (5.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Withdrawal Space - 2hb - (12.73 SQM)	 Student Space (5)	
B00A - R0010 - Staff Room Annexe - (16.3 SQM)	 Office (4)	
B00A - R0012 - Home Base - (64.96 SQM) - Teaching Space: 1	 Student Space (29)	
B00A - R0013 - Home Base - (67.51 SQM) - Teaching Space: 1	 Student Space (33)	
B00B - R0001 - Withdrawal Space - 1hb - (20.59 SQM)	 Student Space (9)	
B00F - R0001 - Canteen - (12.8 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Clerical Office - (19.11 SQM)	 Office (4)	
B00G - R0004 - Sick Bay - (7.6 SQM)	 Student Space (3)	
B00G - R0007 - Movement - (19.49 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Staff Room - (21.16 SQM)	 Office (5)	
B00G - R0009 - Staff Kitchen - (5.56 SQM)	 Office (1)	
B00G - R0011 - Principal - (17.17 SQM)	 Office (4)	
B00G - R0012 - Reading Area - (71.6 SQM)	 Student Space (33)	
OS 602 10142 - OS 602 10142 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15393 - OS 602 15393 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	