

SCHOOL:	Cranebrook High School (8580)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Penrith
LOCAL GOVERNMENT AREA:	Penrith

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Administration - Clerical - (13.2 SQM)	Office (3)	
B00A - R0003 - Principal Office - (19.53 SQM)	Office (4)	
B00A - R0005 - Interview/Meeting - (12.81 SQM)	Office (3)	
B00A - R0010 - Clinic - (15.02 SQM)	Office (3)	
B00A - R0013 - Leading Teacher - (14.52 SQM)	Office (3)	
B00A - R0014 - Deputy Principal Office - (16.69 SQM)	Office (4)	
B00A - R0016 - Deputy Principal Office - (12.66 SQM)	Office (3)	
B00A - R0019 - Administration - Clerical - (48.72 SQM)	Office (12)	
B00A - R0023 - Ancillary Staff - (19.16 SQM)	Office (4)	
B00A - R0025 - Movement - (28.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Public Reception - (30.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Pupil Entry - (36.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Stage - (106.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Multi-Purpose Space - (451.23 SQM)	Student Space (209)	
B00B - R0010 - Staff Kitchen - (9.33 SQM)	Office (2)	
B00B - R0017 - Movement - (19.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - General Assistants - (13.22 SQM)	Office (3)	
B00B - R0033 - Movement - (57.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Staff Study - (18.32 SQM)	Office (4)	
B00C - R0001 - Student Canteen - (52.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Art Learning Space - (63.22 SQM) - Teaching Space: 1	Student Space (58)	
B00D - R0003 - Art Learning Space - (63.31 SQM) - Teaching Space: 1	Student Space (58)	
B00D - R0004 - Art Learning Space - (63.06 SQM) - Teaching Space: 1	Student Space (73)	
B00D - R0013 - Metal Technology Bay - (39.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Wood Technology Bay - (31.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Movement - (18.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Art Learning Space - (62.36 SQM) - Teaching Space: 1	Student Space (58)	
B00D - R0040 - Staff Study - (24.21 SQM)	Office (6)	
B00D - R0042 - Materials Learning Space - Type 1 - (86.28 SQM) - Teaching Space: 1	Student Space (48)	
B00D - R0044 - Materials Technology L.S. - (88.37 SQM) - Teaching Space: 1	Student Space (48)	
B00D - R0046 - Workshop - (69.28 SQM)	Student Space (32)	
B00D - R0049 - Materials Technology L.S. - (79.59 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R0051 - Materials Technology L.S. - (79.47 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R0053 - Staff Study - (42.2 SQM)	Office (10)	
B00D - R0055 - Design L.S. - (55.84 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0057 - Workshop - (65.41 SQM)	Student Space (35)	
B00D - R0061 - Computer Learning Space - (56.38 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0003 - Practice/Seminar - (26.22 SQM)	Student Space (12)	
B00E - R0004 - Music Learning Space - (79.46 SQM) - Teaching Space: 1	Student Space (51)	
B00E - R0006 - Tea Room - (13.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Music Learning Space - (62.27 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0009 - Practice/Seminar - (26.07 SQM)	Student Space (12)	
B00E - R0014 - Staff Study - (17.72 SQM)	Office (4)	
B00F - R0004 - Computer Learning Space - (59.9 SQM) - Teaching Space: 1	Student Space (44)	
B00F - R0007 - Movement - (268.38 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Deputy Principal Office - (14.88 SQM)	Office (3)	
B00F - R0009 - Staff Study - (15.23 SQM)	Office (3)	
B00F - R0010 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0011 - General Learning Space - (47.71 SQM) - Teaching Space: 1	Student Space (37)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0012 - General Learning Space - (47.62 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R0013 - General Learning Space - (47.77 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R0014 - General Learning Space - (47.56 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R0050 - Seminar - (20.99 SQM)	● Office (5)	
B00F - R0056 - Audio Visual Workroom - (36.45 SQM)	● Student Space (22)	
B00F - R0062 - Movement - (260.6 SQM)	Not Applicable	Circulation or storage space.
B00F - R0100 - Special Learning Space - (52.69 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R0106 - Special Learning Space - (47.8 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R0107 - Special Learning Space - (47.58 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R0111 - Special Learning Space - (49.02 SQM) - Teaching Space: 1	● Student Space (37)	
B00F - R0113 - General Learning Space - (54.28 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R0118 - Interview/Office - Type 1 - (15.67 SQM)	● Office (3)	
B00F - R0123 - General Learning Space - (51.54 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0125 - Staff Study - (23.83 SQM)	● Office (5)	
B00F - R0131 - Main Entry - (15.52 SQM)	Not Applicable	Circulation or storage space.
B00F - R0132 - Main Area - (441.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0135 - Staff Study - (43.82 SQM)	● Office (10)	
B00F - R0143 - Dark Room - (13.73 SQM)	● Office (3)	
B00F - R1003 - General Learning Space - (39.97 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R1004 - General Learning Space - (39.62 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R1005 - General Learning Space - (39.81 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R1006 - Movement - (163.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R1007 - General Learning Space - (47.54 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R1008 - General Learning Space - (47.51 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R1009 - General Learning Space - (47.42 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R1010 - General Learning Space - (47.51 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R1011 - General Learning Space - (46.95 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R1017 - General Learning Space - (40.57 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R1018 - Interview/Office - Type 1 - (13.86 SQM)	● Office (3)	
B00F - R1019 - Interview/Office - Type 1 - (12.86 SQM)	● Office (3)	
B00F - R1025 - Movement - (110.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R1027 - General Learning Space - (39.77 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R1028 - General Learning Space - (46.93 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R1029 - General Learning Space - (47.87 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R1030 - General Learning Space - (47.4 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R1031 - General Learning Space - (47.38 SQM) - Teaching Space: 1	● Student Space (52)	
B00F - R1032 - General Learning Space - (47.58 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R1038 - General Learning Space - (39.85 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R1039 - General Learning Space - (39.75 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R1040 - General Learning Space - (39.46 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R1041 - Interview/Office - Type 1 - (14.33 SQM)	● Office (3)	
B00F - R1046 - Movement - (175.53 SQM)	Not Applicable	Circulation or storage space.
B00F - R1048 - Staff Study - (36.05 SQM)	● Office (9)	
B00F - R1051 - Tea Room - (15.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R1052 - Staff Study - (58.81 SQM)	● Office (14)	
B00F - R1053 - Commonroom - (99.71 SQM)	● Office (24)	
B00F - R1054 - Staff Study - (37.96 SQM)	● Office (9)	
B00F - R1058 - Staff Kitchen - (7.35 SQM)	● Office (1)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0001 - Tiered Learning Area - (66.63 SQM)	● Student Space (52)	
B00G - R0002 - Movement - (5.85 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Laboratory L.S. - (90.57 SQM) - Teaching Space: 1	● Student Space (50)	
B00H - R0002 - Laboratory L.S. - (90.79 SQM) - Teaching Space: 1	● Student Space (50)	
B00H - R0003 - Laboratory L.S. - (91.38 SQM) - Teaching Space: 1	● Student Space (50)	
B00H - R0004 - Preparation - Science - (82.87 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Staff Study - (12.56 SQM)	● Office (3)	
B00H - R0008 - Laboratory L.S. - (91.7 SQM) - Teaching Space: 1	● Student Space (50)	
B00H - R0010 - Laboratory L.S. - (92.01 SQM) - Teaching Space: 1	● Student Space (50)	
B00H - R0011 - Laboratory L.S. - (91.53 SQM) - Teaching Space: 1	● Student Space (50)	
B00H - R0020 - Staff Study - (35.39 SQM)	● Office (8)	
B00I - R0001 - Staff Study - (27.09 SQM)	● Office (6)	
B00I - R0004 - Food Technology L.S. - (102.94 SQM) - Teaching Space: 1	● Student Space (56)	
B00I - R0005 - Preparation - (21.23 SQM)	Not Applicable	Circulation or storage space.
B00I - R0010 - Food Technology L.S. - (103.14 SQM) - Teaching Space: 1	● Student Space (56)	
B00I - R0011 - Staff Study - (12.38 SQM)	● Office (3)	
B00I - R0013 - Special Learning Space - (74.98 SQM) - Teaching Space: 1	● Student Space (41)	
B00I - R0018 - Design L.S. - (72.72 SQM) - Teaching Space: 1	● Student Space (40)	
OS 534 15860 - OS 534 15860 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	