

<b>SCHOOL:</b>	<b>Deepwater Public School (1742)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Northern Tablelands</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Glen Innes Severn</b>

1742 - Deepwater Public School  
Site Plan (12469)



Site plan is indicative only and is included to show building numbers used by the Department.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office - (17.83 SQM)	 Office (4)	
B00A - R0005 - Movement - (5.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Staff Room - (21.51 SQM)	 Office (5)	
B00A - R0007 - Principal - (15.59 SQM)	 Office (3)	
B00A - R0009 - Practical Activities - 1hb - (14.51 SQM)	 Student Space (6)	
B00A - R0010 - Home Base - (78.86 SQM) - Teaching Space: 1	 Student Space (168)	
B00B - R0001 - Practical Activities - 1hb - (9.45 SQM)	 Student Space (4)	
B00B - R0004 - Home Base - (46.92 SQM) - Teaching Space: 1	 Student Space (121)	
B00B - R0005 - Home Base - (46.92 SQM) - Teaching Space: 1	 Student Space (121)	
B00B - R0008 - Movement - (37.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Special Programs Room - (7.94 SQM)	 Student Space (3)	
B00C - R0002 - Reading Area - (46.83 SQM)	 Student Space (21)	
B00I - R0002 - Canteen - (24.97 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Special Programs Room - (34.03 SQM)	 Student Space (15)	