


SCHOOL:	Fairfax Public School (1894)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Narrabri

1894 - Fairfax Public School
Site Plan (12511)



1:604

Printed: 20-Mar-2020

Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Communal Space - (93.68 SQM)	 Student Space (43)	
B00A - R1001 - Movement - (23.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Home Base - (53.97 SQM) - Teaching Space: 1	 Student Space (59)	
B00A - R1003 - Withdrawal Space - 1hb - (11.28 SQM)	 Student Space (5)	
B00B - R0001 - Movement - (8.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Staff Room - (8.16 SQM)	 Office (2)	
B00B - R0004 - Home Base - (40.99 SQM) - Teaching Space: 1	 Student Space (51)	
B00C - R0001 - Clerical Office/Workroom - (20.4 SQM)	 Office (5)	
B00D - R0001 - Movement - (17.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Reading Area - (59.98 SQM)	 Student Space (27)	