

<b>SCHOOL:</b>	<b>Field of Mars Environmental Education Centre (5428)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Lane Cove</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Ryde</b>

5428 - Field of Mars Environmental Education Centre  
Site Plan (10984)



Site plan is indicative only and is included to show building numbers used by the Department.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (23.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office/Workroom - (38.75 SQM)	 Office (9)	
B00A - R0005 - Staff Room - (7.66 SQM)	 Office (1)	
B00A - R0014 - Movement - (19.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Practical Activities - (35.26 SQM)	 Student Space (16)	
B00A - R0017 - General Learning Space - (43.42 SQM) - Teaching Space: 1	 Student Space (56)	
B00A - R0018 - General Learning Space - (79.65 SQM) - Teaching Space: 1	 Student Space (112)	
B00A - R0019 - Movement - (33.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (27.16 SQM)	Not Applicable	Circulation or storage space.