


<b>SCHOOL:</b>	<b>Garah Public School (1956)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Northern Tablelands</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Moree Plains</b>

1956 - Garah Public School  
Site Plan (10592)



1:911

Printed: 20-Mar-2020

Site plan is indicative only and is included to show building numbers used by the Department.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Reading Area - (16.22 SQM)	 Student Space (7)	
B00A - R0001 - Clerical Office/Workroom - (22.48 SQM)	 Office (5)	
B00A - R0004 - Movement - (46.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Movement - (14.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Staff Room - (12.99 SQM)	 Office (3)	
B00A - R0010 - Principal - (12.99 SQM)	 Office (3)	
B00A - R0011 - Movement - (72.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Practical Activities - 1hb - (10.39 SQM)	 Student Space (4)	
B00A - R0014 - Sick Bay - (5.7 SQM)	 Student Space (2)	
B00A - R0015 - Home Base - (58.41 SQM) - Teaching Space: 1	 Student Space (32)	
B00A - R0016 - Reading Area - (52.97 SQM)	 Student Space (24)	
B00A - R0017 - Home Base - (52.84 SQM) - Teaching Space: 1	 Student Space (29)	
B00A - R0018 - Practical Activities - 1hb - (19.11 SQM)	 Student Space (8)	
B00A - R0020 - Movement - (15.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Canteen - (18.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (15.11 SQM)	Not Applicable	Circulation or storage space.