

<b>SCHOOL:</b>	<b>Gorokan High School (8515)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wyong</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal Office - (22.79 SQM)	Office (5)	
B00A - R0002 - Deputy Principal Office - (16.16 SQM)	Office (4)	
B00A - R0009 - Deputy Principal Office - (13 SQM)	Office (3)	
B00A - R0021 - Interview/Office - Type 1 - (13.08 SQM)	Office (3)	
B00A - R0022 - Administration - Executive - (13.08 SQM)	Office (3)	
B00A - R0023 - Clinic - Boys - (13.04 SQM)	Office (3)	
B00A - R0024 - Public Reception - (47.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Student Waiting - (46.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Laboratory L.S. - (90.9 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0028 - Preparation - Science - (47.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Laboratory L.S. - (90.91 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0043 - Interview/Office - Type 1 - (21.29 SQM)	Office (5)	
B00A - R0044 - Administration - Clerical - (13.08 SQM)	Office (3)	
B00A - R0050 - Commonroom - (100.28 SQM)	Office (25)	
B00A - R0051 - Staff Kitchen - (13.11 SQM)	Office (3)	
B00A - R0052 - Administration - Clerical - (43.32 SQM)	Office (10)	
B00A - R0053 - Interview/Meeting - (10.14 SQM)	Office (2)	
B00A - R0054 - General Learning Space - (69.99 SQM) - Teaching Space: 1	Student Space (136)	
B00A - R1001 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1002 - General Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1004 - General Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R1005 - General Learning Space - (51.66 SQM) - Teaching Space: 1	Student Space (33)	
B00A - R1009 - Laboratory L.S. - (91.29 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1010 - Preparation - Science - (46.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Laboratory L.S. - (91.28 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1017 - General Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1018 - General Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1020 - General Learning Space - (52.59 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R1021 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R1034 - Staff Study - (38.34 SQM)	Office (9)	
B00A - R1036 - Staff Study - (52.9 SQM)	Office (13)	
B00B - R0001 - Student Canteen - (73.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Multi-Purpose Space - (458.79 SQM)	Student Space (157)	
B00B - R0013 - Movement - (23.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Dark Room - (9.74 SQM)	Office (2)	
B00B - R1001 - Music Learning Space - (70.87 SQM) - Teaching Space: 1	Student Space (48)	
B00B - R1002 - Music Learning Space - (91.77 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R1004 - Food Technology L.S. - (101.27 SQM) - Teaching Space: 1	Student Space (46)	
B00B - R1009 - Food Technology L.S. - (97.53 SQM) - Teaching Space: 1	Student Space (48)	
B00B - R1023 - Preparation - Materials - (17.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R1026 - Coffee Kiosk - (69.8 SQM)	Not Applicable	Circulation or storage space.
B00C - M0003 - Workshop - (15.68 SQM)	Student Space (20)	
B00C - M0004 - Main Area - (232.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Interview/Office - Type 1 - (8.96 SQM)	Office (2)	
B00C - R0003 - Main Area - (221.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Audio Visual Workroom - (24.75 SQM)	Student Space (24)	
B00C - R0007 - Main Entry - (42.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Interview/Office - Type 1 - (11.56 SQM)	Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0023 - Seminar - (21.83 SQM)	Office (5)	
B00D - R0004 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0005 - General Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0007 - General Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0010 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (69)	
B00D - R0016 - General Learning Space - (52.96 SQM) - Teaching Space: 1	Student Space (54)	
B00D - R0017 - General Learning Space - (52.89 SQM)	Student Space (36)	
B00D - R0019 - Movement - (6.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - Senior Study - (84.05 SQM)	Office (21)	
B00D - R0033 - Staff Study - (36.18 SQM)	Office (9)	
B00D - R0038 - General Learning Space - Bd/Cd/Ed - (51.63 SQM) - Teaching Space: 1	Student Space (38)	
B00D - R0039 - Commonroom - (21.43 SQM)	Office (5)	
B00D - R0040 - General Learning Space - Bd/Cd/Ed - (55.95 SQM) - Teaching Space: 1	Student Space (47)	
B00D - R0041 - General Learning Space - Bd/Cd/Ed - (62.71 SQM) - Teaching Space: 1	Student Space (68)	
B00D - R0042 - Movement - (17.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0044 - Staff Study - (25.35 SQM)	Office (6)	
B00D - R0045 - Staff Kitchen - (7.93 SQM)	Office (1)	
B00D - R0048 - Special Learning Space - (51.6 SQM) - Teaching Space: 1	Student Space (54)	
B00D - R1004 - Leading Teacher - (19.63 SQM)	Office (4)	
B00D - R1007 - General Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (38)	
B00D - R1010 - Computer Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (38)	
B00D - R1011 - General Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (38)	
B00D - R1012 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (38)	
B00D - R1013 - General Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R1014 - General Learning Space - (66.42 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R1015 - General Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R1021 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R1022 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R1023 - Interview/Office - Type 1 - (13 SQM)	Office (3)	
B00D - R1027 - Student Waiting - (6.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R1034 - Staff Study - (35.26 SQM)	Office (8)	
B00D - R1036 - Staff Study - (9.81 SQM)	Office (2)	
B00D - R1038 - General Learning Space - Bd/Cd/Ed - (59.46 SQM) - Teaching Space: 1	Student Space (44)	
B00D - R1039 - General Learning Space - Bd/Cd/Ed - (61.64 SQM) - Teaching Space: 1	Student Space (44)	
B00E - R0001 - Staff Kitchen - (16.6 SQM)	Office (4)	
B00E - R0002 - Staff Study - (16.22 SQM)	Office (4)	
B00E - R0004 - Staff Study - (6.63 SQM)	Office (1)	
B00E - R0005 - Laboratory L.S. - (90.64 SQM) - Teaching Space: 1	Student Space (44)	
B00E - R0006 - Preparation - Science - (48.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Laboratory L.S. - (91 SQM) - Teaching Space: 1	Student Space (44)	
B00E - R0011 - Growing/Breeding - (16.45 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Interview/Office - Type 1 - (28.58 SQM)	Office (7)	
B00E - R1003 - General Learning Space - (65.92 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R1004 - General Learning Space - (66.03 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R1005 - General Learning Space - (65.85 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R1006 - General Learning Space - (65.94 SQM) - Teaching Space: 1	Student Space (39)	
B00F - R0001 - Multi-Purpose Space - (620.76 SQM)	Student Space (288)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0002 - Staff Study - (12.29 SQM)	Office (3)	
B00F - R0004 - Staff Study - (25.33 SQM)	Office (6)	
B00F - R0005 - Tea Room - (8.15 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - General Assistants - (34.1 SQM)	Office (8)	
B00H - R0003 - Seminar - Type 1 - (25.58 SQM)	Office (6)	
B00H - R0005 - Computer Learning Space - (71.33 SQM) - Teaching Space: 1	Student Space (41)	
B00H - R0007 - Main Entry - (7.78 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Staff Study - (10.52 SQM)	Office (2)	
B00J - R0001 - General Learning Space - (92.03 SQM) - Teaching Space: 1	Student Space (52)	
B00J - R0002 - Study Space - (18.82 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Deputy Principal Office - (12.85 SQM)	Office (3)	
B00K - R0003 - Clinic - (12.85 SQM)	Office (3)	
B00K - R0004 - Deputy Principal Office - (12.85 SQM)	Office (3)	
B00K - R0006 - Public Reception - (44.33 SQM)	Not Applicable	Circulation or storage space.
B00K - R0009 - Interview/Meeting - (15.16 SQM)	Office (3)	
B00K - R0010 - Clinic - (12.81 SQM)	Office (3)	
B00K - R0011 - Administration - Executive - (10.73 SQM)	Office (2)	
B00K - R0012 - Administration - Clerical - (100.88 SQM)	Office (25)	
B00K - R0013 - Leading Teacher - (13.51 SQM)	Office (3)	
B00K - R0014 - Staff Kitchen - (12.85 SQM)	Office (3)	
B00K - R0019 - Interview/Meeting - (15.16 SQM)	Office (3)	
B00K - R0020 - Principal Office - (17.8 SQM)	Office (4)	
B00K - R0021 - Interview/Meeting - (12.42 SQM)	Office (3)	
B00K - R0022 - Deputy Principal Office - (12.85 SQM)	Office (3)	
B00K - R0023 - Interview/Meeting - (14.64 SQM)	Office (3)	
B00K - R0024 - Movement - (29.64 SQM)	Not Applicable	Circulation or storage space.
B00K - R0025 - Movement - (17.96 SQM)	Not Applicable	Circulation or storage space.
B00K - R0027 - Public Reception - (35.16 SQM)	Not Applicable	Circulation or storage space.
B01B - R0002 - Multi Media Workshop - (52.81 SQM)	Not Applicable	Circulation or storage space.
B01B - R0003 - Art Learning Space - (52.96 SQM) - Teaching Space: 1	Student Space (32)	
B01B - R0004 - Workshop - (52.07 SQM)	Student Space (60)	
B01B - R0006 - Art Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (34)	
B01B - R0019 - Dark Room - (18.67 SQM)	Office (4)	
B01B - R0020 - Staff Study - (33.11 SQM)	Office (8)	
B01B - R1001 - Leading Teacher - (18.82 SQM)	Office (4)	
B01B - R1002 - Design/Technology L.S. - (66.22 SQM) - Teaching Space: 1	Student Space (41)	
B01B - R1016 - Staff Study - (46.28 SQM)	Office (11)	
B01B - R1018 - Design/Technology L.S. - (50.8 SQM) - Teaching Space: 1	Student Space (45)	
B01B - R1020 - Design/Technology L.S. - (63.49 SQM) - Teaching Space: 1	Student Space (41)	
B01B - R1022 - Computer Learning Space - (50.66 SQM) - Teaching Space: 1	Student Space (34)	
B02B - R0010 - Metal Technology L.S. - (123.41 SQM) - Teaching Space: 1	Student Space (62)	
B02B - R0013 - Metal Technology Bay - (65.63 SQM)	Not Applicable	Circulation or storage space.
B03B - R0010 - Wood Technology L.S. - (197.93 SQM) - Teaching Space: 1	Student Space (148)	
B03B - R0015 - Outdoor Workshop - (187.33 SQM)	Not Applicable	Circulation or storage space.
NS 200 10908 - NS 200 10908 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 601 10909 - OS 601 10909 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (92)	