


VENTILATION AUDIT REPORT Version 2

SCHOOL:	Gunnedah High School (8188)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Tamworth
LOCAL GOVERNMENT AREA:	Gunnedah

8188 - Gunnedah High School
Site Plan (10397)



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (14.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Multi-Purpose Space - (266.49 SQM)	● Student Space (123)	
B00A - R0005 - Movement - (6.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Stage - (71.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (6.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Student Canteen - (23.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Movement - (197.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Student Canteen - (39.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Principal Office - (21.95 SQM)	● Office (5)	
B00C - R0004 - Administration - Clerical - (9.39 SQM)	● Office (2)	
B00C - R0005 - Interview/Office - Type 1 - (9.24 SQM)	● Office (2)	
B00C - R0008 - Administration - Clerical - (12.38 SQM)	● Office (3)	
B00C - R0018 - Staff Study - (17.47 SQM)	● Office (4)	
B00C - R0019 - Preparation - (8.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Administration - Executive - (16.66 SQM)	● Office (4)	
B00C - R0029 - Public Reception - (21.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - Administration - Clerical - (21.56 SQM)	● Office (5)	
B00C - R0032 - Movement - (26.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R0034 - Movement - (43.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R0035 - Movement - (21.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0042 - Administration - Clerical - (26.33 SQM)	● Office (6)	
B00C - R0043 - Movement - (63.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0047 - General Learning Space - (55.73 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R0050 - General Learning Space - (56.9 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0051 - Movement - (13.64 SQM)	Not Applicable	Circulation or storage space.
B00C - R0052 - Deputy Principal Office - (18.44 SQM)	● Office (4)	
B00C - R0053 - Deputy Principal Office - (18.28 SQM)	● Office (4)	
B00C - R0055 - General Learning Space - (58.1 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0056 - Preparation - (12.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0057 - Interview/Meeting - (12.76 SQM)	● Office (3)	
B00C - R1002 - General Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (51)	
B00C - R1003 - General Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (64)	
B00C - R1005 - General Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (46)	
B00C - R1006 - General Learning Space - (52.66 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R1007 - General Learning Space - (53.09 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R1008 - Seminar - (19.29 SQM)	● Office (4)	
B00C - R1012 - General Learning Space - (65.33 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R1016 - Interview/Office - Type 1 - (18.68 SQM)	● Office (4)	
B00C - R1021 - Interview/Meeting - (23.62 SQM)	● Office (5)	
B00C - R1022 - Movement - (145.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R1025 - Staff Study - (25.96 SQM)	● Office (6)	
B00D - R0001 - Food Technology L.S. - (64.57 SQM) - Teaching Space: 1	● Student Space (35)	
B00D - R0007 - Materials Technology L.S. - (65.2 SQM) - Teaching Space: 1	● Student Space (36)	
B00D - R0011 - Materials Technology L.S. - (65.33 SQM) - Teaching Space: 1	● Student Space (36)	
B00D - R0012 - Food Technology L.S. - (65.87 SQM) - Teaching Space: 1	● Student Space (36)	
B00D - R0020 - Movement - (148.48 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Staff Study - (40.52 SQM)	● Office (10)	
B00D - R0027 - Preparation - Materials - (18.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0030 - Seminar - Type 1 - (44.3 SQM)	● Office (11)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0031 - Food Technology L.S. - (83.97 SQM) - Teaching Space: 1	Student Space (56)	
B00D - R1002 - General Learning Space - (51.92 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R1007 - General Learning Space - (65.05 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R1008 - General Learning Space - (51.57 SQM) - Teaching Space: 1	Student Space (48)	
B00D - R1009 - General Learning Space - (51.71 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R1010 - Materials Technology L.S. - (64.5 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R1014 - General Learning Space - (51.71 SQM) - Teaching Space: 1	Student Space (48)	
B00D - R1017 - Movement - (139.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R1020 - Staff Study - (14.93 SQM)	Office (3)	
B00D - R1022 - General Learning Space - (58.34 SQM) - Teaching Space: 1	Student Space (42)	
B00G - R0005 - Staff Study - (33.12 SQM)	Office (8)	
B00G - R0009 - General Learning Space - (57.21 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R0027 - Preparation - Science - (39.14 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Laboratory L.S. - (92.01 SQM) - Teaching Space: 1	Student Space (50)	
B00G - R0029 - Laboratory L.S. - (88.72 SQM) - Teaching Space: 1	Student Space (49)	
B00G - R1001 - Practice/Seminar - (12.29 SQM)	Not Applicable	Circulation or storage space.
B00G - R1002 - Practice/Seminar - (12.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R1004 - Music Learning Space - (66.73 SQM) - Teaching Space: 1	Student Space (36)	
B00G - R1005 - Staff Study - (25.98 SQM)	Office (6)	
B00G - R1009 - Music Learning Space - (56.77 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R1010 - Music Learning Space - (53.66 SQM) - Teaching Space: 1	Student Space (29)	
B00G - R1013 - Art Learning Space - (67.18 SQM) - Teaching Space: 1	Student Space (37)	
B00G - R1014 - Art Learning Space - (56.84 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R1017 - Art Learning Space - (51.67 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0001 - Computer Learning Space - (51.91 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0004 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (61)	
B00H - R0005 - Computer Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (61)	
B00H - R0008 - General Learning Space - (53.45 SQM) - Teaching Space: 1	Student Space (42)	
B00H - R0009 - Interview/Office - Type 1 - (27.5 SQM)	Office (6)	
B00H - R0015 - Preparation - (29.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0021 - Laboratory L.S. - (84.84 SQM) - Teaching Space: 1	Student Space (110)	
B00H - R0022 - Laboratory L.S. - (87.34 SQM) - Teaching Space: 1	Student Space (48)	
B00H - R1004 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R1005 - General Learning Space - (53.01 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R1008 - General Learning Space - (52.66 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R1009 - Interview/Office - Type 1 - (27.46 SQM)	Office (6)	
B00H - R1013 - General Learning Space - (52.95 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R1014 - General Learning Space - (52.88 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R1015 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (55)	
B00H - R1017 - Darkroom Space - (51.77 SQM)	Office (12)	
B00I - R0002 - General Assistants - (10.67 SQM)	Office (2)	
B00I - R0008 - Movement - (6.01 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Materials Technology L.S. - (94.78 SQM) - Teaching Space: 1	Student Space (52)	
B00I - R0018 - Metal Technology Bay - (150.56 SQM)	Not Applicable	Circulation or storage space.
B00I - R0022 - Wood Technology Bay - (94.16 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Workroom - (32.41 SQM)	Office (8)	
B00J - R0006 - Audio Visual Workroom - (29.48 SQM)	Student Space (13)	
B00J - R0008 - Main Area - (369.54 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0009 - Seminar - (11.7 SQM)	 Office (2)	
B00J - R0010 - Seminar - (13.59 SQM)	 Office (3)	
B00J - R0011 - Seminar - (12.7 SQM)	 Office (3)	
B00J - R0013 - Staff Study - (27.76 SQM)	 Office (6)	
B00J - R1003 - Interview/Office - Type 1 - (13.86 SQM)	 Office (3)	
B00J - R1004 - General Learning Space - (53.23 SQM) - Teaching Space: 1	 Student Space (29)	
B00J - R1005 - General Learning Space - (53.24 SQM) - Teaching Space: 1	 Student Space (29)	
B00J - R1006 - General Learning Space - (53.38 SQM) - Teaching Space: 1	 Student Space (58)	
B00J - R1007 - General Learning Space - (53.45 SQM) - Teaching Space: 1	 Student Space (83)	
B00J - R1009 - Commonroom - (74.65 SQM)	 Office (18)	
B00J - R1012 - Staff Study - (26.22 SQM)	 Office (6)	
B00K - R0001 - Design L.S. - (53.01 SQM) - Teaching Space: 1	 Student Space (29)	
B00K - R0004 - Seminar/Technology Space - (17.12 SQM)	 Office (4)	
B00K - R0006 - Materials Technology L.S. - (79.95 SQM) - Teaching Space: 1	 Student Space (44)	
B00L - R0006 - Movement - (22.57 SQM)	Not Applicable	Circulation or storage space.
B00N - R0003 - Staff Study - (12.28 SQM)	 Office (3)	
B00N - R0004 - General Learning Space - Bd/Cd/Ed - (36.1 SQM) - Teaching Space: 1	 Student Space (19)	
B00N - R0006 - Staff Kitchen - (12.73 SQM)	 Office (3)	
B00O - R0001 - Gymnasium - (490.76 SQM)	 Student Space (227)	