

# VENTILATION AUDIT REPORT Version 2

<b>SCHOOL:</b>	Jesmond Public School (2234)
<b>AMU REGION:</b>	Hunter/Central Coast
<b>STATE ELECTORATE:</b>	Wallsend
<b>LOCAL GOVERNMENT AREA:</b>	Newcastle

2234 - Jesmond Public School  
Site Plan (10776)



1:526

Printed: 20-Mar-2020

Site plan is indicative only and is included to show building numbers used by the Department.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (21.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Home Base - (53.7 SQM) - Teaching Space: 1	● Student Space (72)	
B00A - R0008 - Practical Activities - 1hb - (9.7 SQM)	● Student Space (4)	
B00B - R0005 - Reading Area - (85.42 SQM)	● Student Space (39)	
B00B - R0009 - Movement - (15.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Seminar/Study - (17.53 SQM)	● Office (4)	
B00B - R0011 - Movement - (14.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Home Base - (62.8 SQM) - Teaching Space: 1	● Student Space (75)	
B00D - R0005 - Withdrawal Space - 1hb - (13.99 SQM)	● Student Space (6)	
B00D - R0006 - Practical Activities - 1hb - (17.18 SQM)	● Student Space (7)	
B00I - R0002 - Clerical Office/Workroom - (21.66 SQM)	● Office (5)	
B00I - R0003 - Movement - (70.74 SQM)	Not Applicable	Circulation or storage space.
B00I - R0011 - Home Base - (56.14 SQM) - Teaching Space: 1	● Student Space (59)	
B00I - R0013 - Withdrawal Space - 1hb - (13.47 SQM)	● Student Space (6)	
B00I - R0014 - Home Base - (56.06 SQM) - Teaching Space: 1	● Student Space (59)	
B00I - R0015 - Home Base - (56.22 SQM) - Teaching Space: 1	● Student Space (59)	
B00I - R0017 - Withdrawal Space - 1hb - (13.73 SQM)	● Student Space (6)	
B00J - R0001 - Home Base - (51.43 SQM) - Teaching Space: 1	● Student Space (63)	
B00J - R0005 - Home Base - (58.39 SQM) - Teaching Space: 1	● Student Space (75)	
B00J - R0008 - Special Programs Room - (44.77 SQM)	● Student Space (20)	
B00J - R0011 - Practical Activities - 1hb - (16.8 SQM)	● Student Space (7)	
B00J - R0012 - Practical Activities - 1hb - (11.67 SQM)	● Student Space (5)	
B00J - R0013 - Movement - (11.12 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Communal Space - (146.16 SQM)	● Student Space (67)	
B00N - R0003 - Movement - (5.47 SQM)	Not Applicable	Circulation or storage space.
B00N - R0004 - Raised Platform - (60.89 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Movement - (11.17 SQM)	Not Applicable	Circulation or storage space.
B00N - R0006 - Movement - (13.4 SQM)	Not Applicable	Circulation or storage space.
NS 300 14074 - NS 300 14074 - FSU/Bulk Store/Toilet - (57 SQM)	Not Applicable	Circulation or storage space.
OS 502 13477 - OS 502 13477 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	
OS 601 16812 - OS 601 16812 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 13317 - OS 602 13317 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19188 - OS 606 19188 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	