


SCHOOL:	Naradhan Public School (2701)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Bland

2701 - Naradhan Public School
Site Plan (11453)



1:767

Printed: 21-Mar-2020

Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0002 - Reading Area - (51.92 SQM)	 Student Space (24)	
B00C - R0001 - Movement - (24.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (53.25 SQM) - Teaching Space: 1	 Student Space (29)	
B00C - R0003 - Clerical Office - (14.54 SQM)	 Office (3)	
B00C - R0004 - Staff Room - (7.71 SQM)	 Office (1)	
B00C - R0006 - Clerical Office - (17.41 SQM)	 Office (4)	
B00C - R0007 - Staff Kitchen - (5.86 SQM)	 Office (1)	