

<b>SCHOOL:</b>	<b>Newcastle Junior School (5704)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Charlestown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

5704 - Newcastle Junior School  
Site Plan (10428)



Site plan is indicative only and is included to show building numbers used by the Department.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (60.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Home Base - S - (46.95 SQM) - Teaching Space: 1	● Student Space (56)	
B00A - R0004 - Practical Activities - S - 1hb - (6.54 SQM)	● Student Space (3)	
B00A - R0005 - Movement - (8.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Home Base - S - (53.19 SQM) - Teaching Space: 1	● Student Space (56)	
B00A - R0008 - Principal - (17.06 SQM)	● Office (4)	
B00A - R0010 - Entry Vestibule - (12.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Duplicating Workroom - (6.66 SQM)	● Office (1)	
B00A - R0013 - Movement - (6.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Clerical Office - (8.1 SQM)	● Office (2)	
B00A - R0015 - Staff Room - (21.61 SQM)	● Office (5)	
B00A - R0016 - Staff Room Annexe - (19.2 SQM)	● Office (4)	
B00B - R0001 - Movement - (22.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Hydrotherapy - Pool - (17.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (9.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Movement - (24.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - S - 1hb - (9.82 SQM)	● Student Space (4)	
B00C - R0003 - Home Base - S - (87.31 SQM) - Teaching Space: 1	● Student Space (71)	
B00C - R0004 - Movement - (45.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Home Base - M - (73.89 SQM) - Teaching Space: 1	● Student Space (60)	
B00C - R0007 - Practical Activities - M - 1hb - (14.74 SQM)	● Student Space (6)	
B00E - R0001 - Hydrotherapy - Pool - (196.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (37.41 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Entry Vestibule - (10.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Communal Space - (130.72 SQM)	● Student Space (60)	
BOE1 - R0002 - Reading Area - (70.57 SQM)	● Student Space (32)	
BOE1 - R0003 - Reading Area - (70.79 SQM)	● Student Space (32)	
NS 120 16789 - NS 120 16789 - Learning Unit Primary Single - PWD - (76 SQM)	● Student Space (35)	
OS 508 15105 - OS 508 15105 - Administration - (114 SQM)	● Office (28)	
OS 523 15413 - OS 523 15413 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 621 11340 - OS 621 11340 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 621 13465 - OS 621 13465 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	