

SCHOOL:	Newrybar Public School (2741)
AMU REGION:	North Coast
STATE ELECTORATE:	Ballina
LOCAL GOVERNMENT AREA:	Ballina

2741 - Newrybar Public School
Site Plan (11838)



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (25.92 SQM)	Office (6)	
B00A - R0002 - Staff Room - (12.51 SQM)	Office (3)	
B00A - R0005 - Staff Room Annexe - (17.04 SQM)	Office (4)	
B00A - R0006 - Movement - (28.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Canteen - (20.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (50.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (60.05 SQM) - Teaching Space: 1	Student Space (112)	
B00B - R0003 - Movement - (18.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Practical Activities - 1hb - (15.43 SQM)	Student Space (7)	
B00B - R0005 - Withdrawal Space - 1hb - (12.56 SQM)	Student Space (5)	
B00B - R0008 - Practical Activities - 1hb - (15.36 SQM)	Student Space (7)	
B00B - R0009 - Home Base - (60.2 SQM) - Teaching Space: 1	Student Space (112)	
B00B - R0010 - Movement - (18.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (11.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (21.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (40.09 SQM) - Teaching Space: 1	Student Space (70)	
B00C - R0006 - Principal - (10.11 SQM)	Office (2)	
B00C - R0007 - Clerical Office - (16.6 SQM)	Office (4)	
B00C - R0009 - Withdrawal Space - 1hb - (25.86 SQM)	Student Space (11)	
B00C - R0010 - Practical Activities - 1hb - (15.17 SQM)	Student Space (7)	
B00D - R0001 - Movement - (27.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Canteen - (17.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (13.48 SQM)	Not Applicable	Circulation or storage space.