


SCHOOL:	Newtown North Public School (2744)
AMU REGION:	Sydney
STATE ELECTORATE:	Newtown
LOCAL GOVERNMENT AREA:	Sydney



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Withdrawal Space - 1hb - (6.26 SQM)	● Student Space (2)	
B00A - R0003 - Practical Activities - 1hb - (21.7 SQM)	● Student Space (10)	
B00A - R0004 - Movement - (7.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Staff Room - (46.86 SQM)	● Office (11)	
B00A - R0008 - Interview - (9.3 SQM)	● Office (2)	
B00A - R0009 - Principal - (12.56 SQM)	● Office (3)	
B00A - R0011 - Movement - (41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (6.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Sick Bay - (8.98 SQM)	● Student Space (4)	
B00A - R0016 - Movement - (10.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Communal Space - (117.44 SQM)	● Student Space (54)	
B00A - R0020 - Duplicating Workroom - (22.8 SQM)	● Office (5)	
B00A - R0021 - Reading Area - (139.89 SQM)	● Student Space (64)	
B00A - R0022 - Movement - (25.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (9.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Practical Activities - 1hb - (15.68 SQM)	● Student Space (7)	
B00A - R0026 - Home Base - (60.4 SQM) - Teaching Space: 1	● Student Space (34)	
B00A - R0027 - Home Base - (54.73 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0028 - Raised Platform - (30.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Clerical Office - (25.01 SQM)	● Office (6)	
B00A - R1001 - Deputy Principal - (13.38 SQM)	● Office (3)	
B00A - R1002 - Practical Activities - 1hb - (36.5 SQM)	● Student Space (16)	
B00A - R1003 - Home Base - (57.28 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R1004 - Home Base - (57.22 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R1005 - Movement - (68.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Practical Activities - 1hb - (11.21 SQM)	● Student Space (5)	
B00A - R1007 - Movement - (57.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Home Base - (70.26 SQM) - Teaching Space: 1	● Student Space (38)	
B00A - R1013 - Home Base - (68.54 SQM) - Teaching Space: 1	● Student Space (37)	
B00A - R1014 - Staff Room Annexe - (25.24 SQM)	● Office (6)	
B00A - R1015 - Home Base - (57.66 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R1016 - Home Base - (56.73 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R9001 - Movement - (12.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R9007 - Movement - (14.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R9012 - Home Base - (58.22 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R9017 - Home Base - (54.97 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R9018 - Movement - (22.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R9019 - Practical Activities - 1hb - (32.16 SQM)	● Student Space (14)	
B00A - R9020 - Home Base - (59.07 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R9021 - Home Base - (60.63 SQM) - Teaching Space: 1	● Student Space (34)	
B00A - R9022 - Practical Activities - 1hb - (32.99 SQM)	● Student Space (15)	
B00A - R9023 - Movement - (41.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R9024 - Movement - (5.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R9025 - Clerical Office - (5.47 SQM)	● Office (1)	
B00B - R0004 - Movement - (20.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Practical Activities - 1hb - (10.58 SQM)	● Student Space (4)	
B00B - R0007 - Special Programs Room - (25.84 SQM)	● Student Space (11)	
B00F - R0001 - Special Programs Room - (30.82 SQM)	● Student Space (14)	
B00F - R0002 - Home Base - (31.12 SQM) - Teaching Space: 1	● Student Space (17)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0003 - Special Programs Room - (36.97 SQM)	 Student Space (17)	
B00F - R0004 - Movement - (15.12 SQM)	Not Applicable	Circulation or storage space.