

SCHOOL:	Northlakes High School (8547)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Swansea
LOCAL GOVERNMENT AREA:	Central Coast

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Leading Teacher - (9.65 SQM)	Office (2)	
B00A - R0003 - Deputy Principal Office - (13.81 SQM)	Office (3)	
B00A - R0006 - Clinic - (15.22 SQM)	Office (3)	
B00A - R0007 - Deputy Principal Office - (16.08 SQM)	Office (4)	
B00A - R0014 - Principal Office - (20.05 SQM)	Office (5)	
B00A - R0022 - Public Reception - (14.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (27.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Student Reception - (21.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Administration - Clerical - (8.55 SQM)	Office (2)	
B00A - R0027 - Ancillary Staff - (15.52 SQM)	Office (3)	
B00A - R0031 - Administration - Clerical - (67.88 SQM)	Office (16)	
B00A - R0032 - Administration - Clerical - (16.96 SQM)	Office (4)	
B00B - R0002 - Metal Technology Bay - (29.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Wood Technology Bay - (29.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (99.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Metal Technology L.S. - (54.4 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0025 - Wood Technology L.S. - (89.72 SQM) - Teaching Space: 1	Student Space (88)	
B00B - R0027 - Wood Technology L.S. - (89.9 SQM) - Teaching Space: 1	Student Space (123)	
B00B - R0029 - Metal Technology L.S. - (89.41 SQM) - Teaching Space: 1	Student Space (97)	
B00B - R0033 - Metal Technology L.S. - (91.45 SQM) - Teaching Space: 1	Student Space (70)	
B00B - R1005 - Movement - (16.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - Design/Technology L.S. - (61.19 SQM) - Teaching Space: 1	Student Space (63)	
B00B - R1009 - Staff Study - (26.72 SQM)	Office (6)	
B00B - R1011 - Design/Technology L.S. - (54.77 SQM) - Teaching Space: 1	Student Space (54)	
B00C - R0001 - Music Learning Space - (80.34 SQM) - Teaching Space: 1	Student Space (58)	
B00C - R0003 - Multi Media Studio - (31.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Art Learning Space - (56.16 SQM) - Teaching Space: 1	Student Space (54)	
B00C - R0008 - Art Learning Space - (61.6 SQM) - Teaching Space: 1	Student Space (90)	
B00C - R0009 - Art Learning Space - (58.82 SQM) - Teaching Space: 1	Student Space (77)	
B00C - R0010 - Art Learning Space - (60.02 SQM) - Teaching Space: 1	Student Space (77)	
B00C - R0011 - Practice/Seminar - (27.98 SQM)	Student Space (90)	
B00C - R0023 - Movement - (79.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Practice/Seminar - (14.15 SQM)	Student Space (63)	
B00C - R1007 - Art Learning Space - (63.94 SQM) - Teaching Space: 1	Student Space (41)	
B00C - R1009 - Practice/Seminar - (25.99 SQM)	Student Space (27)	
B00C - R1010 - Music Learning Space - (62.06 SQM) - Teaching Space: 1	Student Space (40)	
B00C - R1012 - Performance Workshop - (82.56 SQM)	Student Space (63)	
B00C - R1016 - Staff Study - (28.37 SQM)	Office (7)	
B00C - R1018 - Movement - (40.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - General Learning Space - (48.92 SQM) - Teaching Space: 1	Student Space (67)	
B00D - R0003 - General Learning Space - (49.47 SQM) - Teaching Space: 1	Student Space (45)	
B00D - R0008 - General Learning Space - (47.81 SQM) - Teaching Space: 1	Student Space (58)	
B00D - R0009 - General Learning Space - (49.68 SQM) - Teaching Space: 1	Student Space (51)	
B00D - R0011 - General Learning Space - (49.12 SQM) - Teaching Space: 1	Student Space (51)	
B00D - R0012 - General Learning Space - (48.77 SQM) - Teaching Space: 1	Student Space (51)	
B00D - R0014 - General Learning Space - (48.13 SQM) - Teaching Space: 1	Student Space (56)	
B00D - R0015 - General Learning Space - (48.13 SQM) - Teaching Space: 1	Student Space (61)	
B00D - R0016 - General Learning Space - (42.34 SQM) - Teaching Space: 1	Student Space (61)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0017 - Interview/Office - Type 1 - (16.74 SQM)	Office (4)	
B00D - R0022 - Interview/Office - Type 1 - (13.83 SQM)	Office (3)	
B00D - R0023 - Interview/Office - Type 1 - (12.66 SQM)	Office (3)	
B00D - R0027 - Interview/Office - Type 1 - (12.44 SQM)	Office (3)	
B00D - R0030 - Staff Study - (17.8 SQM)	Office (4)	
B00D - R0033 - General Learning Space - (42.49 SQM) - Teaching Space: 1	Student Space (61)	
B00D - R0034 - General Learning Space - (47.95 SQM)	Student Space (22)	
B00D - R0035 - General Learning Space - (48.34 SQM) - Teaching Space: 1	Student Space (54)	
B00D - R0037 - General Learning Space - (48.67 SQM) - Teaching Space: 1	Student Space (67)	
B00D - R0038 - Movement - (480.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0040 - Audio Visual Workroom - (33.54 SQM)	Student Space (15)	
B00D - R0041 - Computer Learning Space - (46.07 SQM) - Teaching Space: 1	Student Space (40)	
B00D - R0051 - Main Entry - (22.05 SQM)	Not Applicable	Circulation or storage space.
B00D - R0052 - Senior Study - (79.73 SQM)	Office (19)	
B00D - R0053 - Senior Study - (33.61 SQM)	Office (8)	
B00D - R0054 - Seminar - (13.99 SQM)	Office (3)	
B00D - R0055 - Seminar - (13.99 SQM)	Office (3)	
B00D - R0056 - Seminar - (14.2 SQM)	Office (3)	
B00D - R0058 - Main Area - (336.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0062 - Tiered Learning Area - (22.2 SQM)	Student Space (10)	
B00D - R0064 - Staff Lounge - (75.13 SQM)	Office (18)	
B00D - R0065 - Staff Kitchen - (10.99 SQM)	Office (2)	
B00D - R0066 - Staff Study - (33.6 SQM)	Office (8)	
B00D - R1001 - General Learning Space - (49.68 SQM) - Teaching Space: 1	Student Space (48)	
B00D - R1002 - General Learning Space - (47.89 SQM) - Teaching Space: 1	Student Space (65)	
B00D - R1003 - General Learning Space - (40.77 SQM) - Teaching Space: 1	Student Space (58)	
B00D - R1004 - Staff Study - (40.24 SQM)	Office (10)	
B00D - R1005 - General Learning Space - (40.67 SQM) - Teaching Space: 1	Student Space (81)	
B00D - R1006 - General Learning Space - (47.94 SQM) - Teaching Space: 1	Student Space (65)	
B00D - R1007 - General Learning Space - (49.65 SQM) - Teaching Space: 1	Student Space (54)	
B00D - R1009 - General Learning Space - (49.47 SQM) - Teaching Space: 1	Student Space (65)	
B00D - R1010 - General Learning Space - (48.74 SQM) - Teaching Space: 1	Student Space (65)	
B00D - R1012 - General Learning Space - (48.38 SQM) - Teaching Space: 1	Student Space (55)	
B00D - R1013 - Computer Learning Space - (47.83 SQM) - Teaching Space: 1	Student Space (55)	
B00D - R1014 - Computer Learning Space - (42.15 SQM) - Teaching Space: 1	Student Space (54)	
B00D - R1016 - Shared Study Space - (15.86 SQM)	Office (3)	
B00D - R1021 - Shared Study Space - (12.83 SQM)	Office (3)	
B00D - R1022 - Tiered Learning Area - (45.7 SQM)	Student Space (21)	
B00D - R1023 - Leading Teacher - (12.86 SQM)	Office (3)	
B00D - R1024 - Interview/Office - Type 1 - (15.22 SQM)	Office (3)	
B00D - R1031 - General Learning Space - (42.45 SQM) - Teaching Space: 1	Student Space (70)	
B00D - R1032 - General Learning Space - (48.1 SQM) - Teaching Space: 1	Student Space (70)	
B00D - R1033 - Computer Learning Space - (48.32 SQM) - Teaching Space: 1	Student Space (45)	
B00D - R1035 - General Learning Space - (48.8 SQM) - Teaching Space: 1	Student Space (70)	
B00D - R1036 - General Learning Space - (49.23 SQM) - Teaching Space: 1	Student Space (70)	
B00D - R1040 - Special Learning Space - (29.93 SQM) - Teaching Space: 1	Student Space (33)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1044 - Movement - (350.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R1045 - Staff Study - (32.59 SQM)	Office (8)	
B00D - R1047 - Staff Study - (38.1 SQM)	Office (9)	
B00E - R0001 - Laboratory L.S. - (80.06 SQM) - Teaching Space: 1	Student Space (69)	
B00E - R0002 - Preparation - Science - (31.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Laboratory L.S. - (79.71 SQM) - Teaching Space: 1	Student Space (58)	
B00E - R0006 - Laboratory L.S. - (80.43 SQM) - Teaching Space: 1	Student Space (54)	
B00E - R0007 - Preparation - Science - (31.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Laboratory L.S. - (81.23 SQM) - Teaching Space: 1	Student Space (54)	
B00E - R0014 - Laboratory L.S. - (79.98 SQM) - Teaching Space: 1	Student Space (64)	
B00E - R0016 - Laboratory L.S. - (80.34 SQM) - Teaching Space: 1	Student Space (59)	
B00E - R0018 - Tea Room - (12.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (211.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R0027 - Dark Room - (28.57 SQM)	Office (7)	
B00E - R0029 - Staff Study - (39.09 SQM)	Office (9)	
B00E - R1001 - Food Technology L.S. - (105.84 SQM) - Teaching Space: 1	Student Space (81)	
B00E - R1004 - Food Technology L.S. - (106.22 SQM) - Teaching Space: 1	Student Space (81)	
B00E - R1007 - Computer Learning Space - (71.44 SQM) - Teaching Space: 1	Student Space (81)	
B00E - R1009 - Design L.S. - (70.84 SQM) - Teaching Space: 1	Student Space (81)	
B00E - R1010 - Movement - (90.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R1018 - Preparation - Materials - (32.87 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Student Canteen - (64.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Interview/Meeting - (8.37 SQM)	Office (2)	
B00G - R0011 - General Assistants - (12.05 SQM)	Office (3)	
B00G - R0015 - Movement - (5.79 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Movement - (9.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Stage - (101.57 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Movement - (10.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Movement - (5.58 SQM)	Not Applicable	Circulation or storage space.
B00G - R0021 - Multi-Purpose Space - (472.94 SQM)	Student Space (219)	
B00G - R0025 - Interview/Office - Type 1 - (22.18 SQM)	Office (5)	
B00G - R9003 - Movement - (16.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R9008 - Movement - (16.77 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Growing/Breeding - (10.82 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Growing/Breeding - (24.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Growing/Breeding - (26.29 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Growing/Breeding - (15.97 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Growing/Breeding - (27.35 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Seminar - Type 1 - (20.69 SQM)	Office (5)	
B00I - R0009 - Interview/Meeting - (12.51 SQM)	Office (3)	
B00I - R0016 - Special Learning Space - (53.1 SQM) - Teaching Space: 1	Student Space (76)	
B00I - R0018 - Special Learning Space - (52 SQM) - Teaching Space: 1	Student Space (88)	
B00I - R0020 - Staff Study - (52.4 SQM)	Office (13)	
B00J - R0001 - Computer Learning Space - (64.64 SQM) - Teaching Space: 1	Student Space (119)	
B00J - R0003 - General Learning Space - (59.69 SQM) - Teaching Space: 1	Student Space (54)	
B00J - R0004 - General Learning Space - (59.54 SQM) - Teaching Space: 1	Student Space (54)	
B00J - R0005 - Staff Study - (24.23 SQM)	Office (6)	
B00J - R0006 - General Learning Space - (59.61 SQM) - Teaching Space: 1	Student Space (54)	
B00J - R0007 - General Learning Space - (59.68 SQM) - Teaching Space: 1	Student Space (54)	
B00J - R0009 - General Learning Space - (59.6 SQM) - Teaching Space: 1	Student Space (54)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0010 - Seminar/Study - (123.5 SQM)	 Office (30)	
B00K - R0001 - Fitness Laboratory - (51.25 SQM)	 Student Space (23)	
B00L - R0001 - Preparation - Materials - (23.61 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Food Technology L.S. - (122.46 SQM) - Teaching Space: 1	 Student Space (103)	
B00L - R0004 - Food/Research Space - (40.96 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Food/Research Space - (15.19 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - General Learning Space - (91.84 SQM) - Teaching Space: 1	 Student Space (55)	
B00M - R0002 - Staff Study - (18.7 SQM)	 Office (4)	
B00M - R0004 - Staff Kitchen - (9.04 SQM)	 Office (2)	