

<b>SCHOOL:</b>	<b>Port Hacking High School (8230)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Miranda</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Study - (20.23 SQM)	Office (5)	
B00A - R0008 - Administration - Clerical - (13.03 SQM)	Office (3)	
B00A - R0009 - Principal Office - (15.96 SQM)	Office (3)	
B00A - R0018 - Deputy Principal Office - (17.39 SQM)	Office (4)	
B00A - R0020 - Commonroom - (74.66 SQM)	Office (18)	
B00A - R0021 - Preparation - (21.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - General Learning Space - (38.23 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0026 - Preparation - (14.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (17.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Movement - (20.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Staff Kitchen - (9.78 SQM)	Office (2)	
B00A - R0042 - Staff Study - (29.31 SQM)	Office (7)	
B00A - R0048 - General Learning Space - (59.02 SQM) - Teaching Space: 1	Student Space (50)	
B00A - R0049 - Science Laboratory - (17.22 SQM)	Student Space (10)	
B00A - R0050 - General Learning Space - (61.61 SQM) - Teaching Space: 1	Student Space (50)	
B00A - R0051 - Science Laboratory - (12.98 SQM)	Student Space (10)	
B00A - R0052 - Movement - (236.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Pupil Entry - (19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0056 - Public Reception - (13.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0057 - Movement - (49.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0058 - Public Reception - (13.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Staff Study - (16.05 SQM)	Office (4)	
B00A - R1003 - Movement - (12.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Interview/Office - Type 1 - (8.3 SQM)	Office (2)	
B00A - R1010 - Administration - Clerical - (11.36 SQM)	Office (2)	
B00A - R1011 - Performance Workspace - (90.16 SQM) - Teaching Space: 1	Student Space (80)	
B00A - R1016 - Movement - (42.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - General Learning Space - (56.46 SQM) - Teaching Space: 1	Student Space (50)	
B00A - R1018 - General Learning Space - (56.13 SQM) - Teaching Space: 1	Student Space (50)	
B00A - R1019 - General Learning Space - (55.09 SQM) - Teaching Space: 1	Student Space (50)	
B00A - R1020 - General Learning Space - (57.75 SQM) - Teaching Space: 1	Student Space (50)	
B00A - R1021 - General Learning Space - (55.3 SQM) - Teaching Space: 1	Student Space (50)	
B00A - R1022 - General Learning Space - (58.21 SQM) - Teaching Space: 1	Student Space (50)	
B00A - R1023 - Staff Study - (19.03 SQM)	Office (4)	
B00A - R1024 - Staff Study - (39.88 SQM)	Office (9)	
B00A - R1031 - Movement - (14.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R1033 - Movement - (251.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R9004 - Student Canteen - (56.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R9008 - Student Canteen - (13.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R9012 - Movement - (291.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R9017 - Movement - (142.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R9021 - Movement - (8.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R9026 - Movement - (21.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - General Learning Space - (60.74 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0003 - General Learning Space - (54.58 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0011 - Movement - (11.85 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Movement - (13.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Student Waiting - (19.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Administration - Clerical - (20.43 SQM)	Office (5)	
B00B - R0018 - Deputy Principal Office - (19.17 SQM)	Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0019 - Leading Teacher - (9.97 SQM)	Office (2)	
B00B - R0020 - Movement - (36.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Deputy Principal Office - (17.62 SQM)	Office (4)	
B00B - R1002 - General Learning Space - (59.16 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1003 - General Learning Space - (54.51 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1004 - General Learning Space - (54.74 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1010 - Movement - (11.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R1011 - Movement - (61 SQM)	Not Applicable	Circulation or storage space.
B00B - R9001 - Movement - (17.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R9003 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R9009 - Movement - (12.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R9011 - Movement - (5.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R9013 - Movement - (22.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R9016 - Movement - (5.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R9018 - Movement - (5.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Computer Learning Space - (50.43 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R0017 - Staff Study - (16.56 SQM)	Office (4)	
B00C - R0020 - Food Technology L.S. - (80.8 SQM) - Teaching Space: 1	Student Space (67)	
B00C - R0021 - Preparation - (16.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Food Technology L.S. - (75.28 SQM) - Teaching Space: 1	Student Space (61)	
B00C - R0023 - Food Technology L.S. - (75.2 SQM) - Teaching Space: 1	Student Space (61)	
B00C - R0025 - Movement - (171.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R1005 - Staff Study - (14.53 SQM)	Office (3)	
B00C - R1006 - Staff Study - (7.27 SQM)	Office (1)	
B00C - R1007 - General Learning Space - (67.49 SQM) - Teaching Space: 1	Student Space (45)	
B00C - R1010 - General Learning Space - (66.46 SQM) - Teaching Space: 1	Student Space (45)	
B00C - R1011 - Design L.S. - (67.37 SQM) - Teaching Space: 1	Student Space (45)	
B00C - R1014 - Design L.S. - (50.36 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R1016 - General Learning Space - (55.2 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R1017 - Staff Study - (16.72 SQM)	Office (4)	
B00C - R1020 - Movement - (170.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R9002 - Staff Study - (16.6 SQM)	Office (4)	
B00C - R9005 - Staff Study - (22 SQM)	Office (5)	
B00C - R9006 - Darkroom Space - (31.13 SQM)	Office (7)	
B00C - R9009 - Practice/Seminar - (32.56 SQM)	Student Space (15)	
B00C - R9012 - Music Learning Space - (66.68 SQM) - Teaching Space: 1	Student Space (45)	
B00C - R9013 - Practice/Seminar - (17.02 SQM)	Student Space (7)	
B00C - R9014 - Art Learning Space - (48.39 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R9015 - Art Learning Space - (50.01 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R9017 - Staff Kitchen - (11.22 SQM)	Office (2)	
B00C - R9020 - Study Space - (28.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R9021 - Study Space - (13.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R9026 - Movement - (187.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - General Learning Space - (53.52 SQM) - Teaching Space: 1	Student Space (49)	
B00D - R0002 - Movement - (59.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (49)	
B00D - R0004 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (56)	
B00D - R0005 - General Learning Space - (53.37 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0006 - Interview/Office - Type 1 - (18.46 SQM)	Office (4)	
B00D - R0007 - Interview/Office - Type 1 - (23.86 SQM)	Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0008 - General Learning Space - (53.44 SQM) - Teaching Space: 1	● Student Space (56)	
B00D - R0009 - General Learning Space - (53.45 SQM) - Teaching Space: 1	● Student Space (56)	
B00E - R0003 - Design/Technology L.S. - (76.27 SQM) - Teaching Space: 1	● Student Space (56)	
B00E - R0006 - Welding Area - (22.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Materials Technology L.S. - (76.36 SQM) - Teaching Space: 1	● Student Space (56)	
B00E - R0009 - Staff Study - (31 SQM)	● Office (7)	
B00E - R0012 - Computer Learning Space - (68.53 SQM) - Teaching Space: 1	● Student Space (50)	
B00E - R0013 - Design L.S. - (63.69 SQM) - Teaching Space: 1	● Student Space (50)	
B00E - R0014 - Materials Technology L.S. - (75.43 SQM) - Teaching Space: 1	● Student Space (56)	
B00E - R0026 - Movement - (14.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R0029 - Wood Technology Bay - (132 SQM)	Not Applicable	Circulation or storage space.
B00E - R0030 - Wood Technology Bay - (132.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R0031 - Movement - (75.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R9005 - Movement - (12.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R9009 - Movement - (11.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - General Assistants - (7.95 SQM)	● Office (1)	
B00F - R0005 - Multi-Purpose Space - (365.45 SQM)	● Student Space (169)	
B00F - R0007 - Movement - (17.62 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (13.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R1011 - Science Laboratory - (54.04 SQM)	● Student Space (65)	
B00F - R1012 - General Learning Space - (39.69 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R1013 - Preparation - Science - (40.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R1014 - Science Laboratory - (50.89 SQM)	● Student Space (65)	
B00F - R1015 - General Learning Space - (41.43 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R1016 - Movement - (145.62 SQM)	Not Applicable	Circulation or storage space.
B00F - R2003 - Movement - (17.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R2008 - Workroom - (9.48 SQM)	● Office (2)	
B00F - R2009 - General Learning Space - (53.44 SQM) - Teaching Space: 1	● Student Space (45)	
B00F - R2015 - Movement - (74.63 SQM)	Not Applicable	Circulation or storage space.
B00F - R2017 - Staff Study - (35.35 SQM)	● Office (8)	
B00F - R2018 - General Learning Space - (42.66 SQM) - Teaching Space: 1	● Student Space (45)	
B00F - R2019 - General Learning Space - (51.58 SQM) - Teaching Space: 1	● Student Space (55)	
B00F - R2020 - General Learning Space - (51.59 SQM) - Teaching Space: 1	● Student Space (60)	
B00F - R2021 - Movement - (43.85 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Preparation - (29.92 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Preparation - (10.08 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Staff Study - (26.71 SQM)	● Office (6)	
B00G - R0015 - General Learning Space - (53.75 SQM) - Teaching Space: 1	● Student Space (60)	
B00G - R0017 - Movement - (13.86 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Movement - (23.04 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Movement - (72.8 SQM)	Not Applicable	Circulation or storage space.
B00G - R0021 - Movement - (14.15 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Science Laboratory - (93.14 SQM)	● Student Space (95)	
B00G - R0028 - Science Laboratory - (92.19 SQM)	● Student Space (95)	
B00G - R1002 - General Learning Space - (57.58 SQM) - Teaching Space: 1	● Student Space (65)	
B00G - R1004 - General Learning Space - (62.35 SQM) - Teaching Space: 1	● Student Space (65)	
B00G - R1005 - General Learning Space - (62.35 SQM) - Teaching Space: 1	● Student Space (75)	
B00G - R1011 - Administration - Clerical - (19.37 SQM)	● Office (4)	
B00G - R1012 - Staff Study - (28.01 SQM)	● Office (7)	
B00G - R1013 - General Learning Space - (54.34 SQM) - Teaching Space: 1	● Student Space (55)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1017 - Movement - (14.32 SQM)	Not Applicable	Circulation or storage space.
B00G - R1018 - Movement - (34.88 SQM)	Not Applicable	Circulation or storage space.
B00G - R1019 - Movement - (68.39 SQM)	Not Applicable	Circulation or storage space.
B00G - R9001 - Music Learning Space - (54.18 SQM) - Teaching Space: 1	● Student Space (60)	
B00G - R9003 - Art Learning Space - (60.54 SQM) - Teaching Space: 1	● Student Space (60)	
B00G - R9005 - Art Learning Space - (53.6 SQM) - Teaching Space: 1	● Student Space (50)	
B00G - R9013 - Movement - (13.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R9014 - Movement - (73.9 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Stage - (123.11 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Movement - (8.32 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Movement - (12.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Staff Kitchen - (9.97 SQM)	● Office (2)	
B00H - R0015 - Multi-Purpose Space - (458.72 SQM)	● Student Space (40)	
B00J - R0014 - Lecture Space - (60.61 SQM) - Teaching Space: 2	● Student Space (34)	
B00J - R0016 - Seminar - (13.95 SQM)	● Office (3)	
B00J - R0018 - Pupil Entry - (29.12 SQM)	Not Applicable	Circulation or storage space.
B00J - R0020 - Movement - (23.91 SQM)	Not Applicable	Circulation or storage space.
B00J - R0023 - Study Space - (335.29 SQM)	Not Applicable	Circulation or storage space.
B00J - R0024 - Seminar - (14.19 SQM)	● Office (3)	
B00J - R0025 - Seminar - (13.85 SQM)	● Office (3)	
B00J - R0028 - Movement - (9.75 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Performance Workshop - (102.17 SQM)	● Student Space (57)	
B00L - R0001 - Gymnasium - (619.03 SQM)	● Student Space (367)	
B00L - R0003 - Teachers Aides - (18.3 SQM)	● Office (4)	
B00L - R0008 - Movement - (15.12 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Dark Room - (99.21 SQM)	● Office (24)	
B00L - R0011 - Music Learning Space - (99.29 SQM) - Teaching Space: 1	● Student Space (46)	
B00L - R0012 - Movement Studio - (120.45 SQM)	Not Applicable	Circulation or storage space.
OS 520 12023 - OS 520 12023 - Staff Study - (57 SQM)	● Office (14)	
OS 600 10928 - OS 600 10928 - Learning Unit - Small - (57 SQM)	● Student Space (56)	
OS 600 11454 - OS 600 11454 - Learning Unit - Small - (76 SQM)	● Student Space (56)	
OS 600 18332 - OS 600 18332 - Learning Unit - Small - (57 SQM)	● Student Space (56)	
OS 601 13369 - OS 601 13369 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (67)	