

SCHOOL:	Rockdale Public School (2973)
AMU REGION:	Sydney
STATE ELECTORATE:	Rockdale
LOCAL GOVERNMENT AREA:	Bayside

2973 - Rockdale Public School
Site Plan (12101)



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (7.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Communal Space - (163.98 SQM)	● Student Space (76)	
B00A - R0006 - Raised Platform - (26.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Canteen - (28.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (54.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (21.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Reading Area - (257.58 SQM)	● Student Space (119)	
B00A - R1004 - Seminar/Study - (8.55 SQM)	● Office (2)	
B00A - R1013 - Movement - (9.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Movement - (55.96 SQM)	Not Applicable	Circulation or storage space.
B00B - M0001 - Movement - (15.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (18.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Practical Activities - 1hb - (13.23 SQM)	● Student Space (6)	
B00B - R0004 - Home Base - (47.97 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0006 - Withdrawal Space - 1hb - (27.4 SQM)	● Student Space (12)	
B00B - R0007 - Withdrawal Space - 1hb - (14.77 SQM)	● Student Space (6)	
B00B - R0008 - Practical Activities - 1hb - (11.92 SQM)	● Student Space (5)	
B00B - R0009 - Practical Activities - 1hb - (17.95 SQM)	● Student Space (8)	
B00B - R0010 - Home Base - (63.14 SQM) - Teaching Space: 1	● Student Space (35)	
B00B - R0012 - Home Base - (47.03 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0013 - Practical Activities - 1hb - (16.7 SQM)	● Student Space (7)	
B00B - R0020 - Movement - (86.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (9.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Staff Room Annexe - (15.07 SQM)	● Office (3)	
B00B - R0024 - Staff Room Annexe - (11.59 SQM)	● Office (2)	
B00B - R0025 - Home Base - (41.59 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0026 - Practical Activities - 1hb - (11.19 SQM)	● Student Space (5)	
B00B - R0027 - Practical Activities - 1hb - (10.69 SQM)	● Student Space (4)	
B00B - R0028 - Home Base - (40.67 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0030 - Movement - (39.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Movement - (32.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Practical Activities - 1hb - (11.02 SQM)	● Student Space (5)	
B00B - R1003 - Home Base - (44.84 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1004 - Home Base - (57.92 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R1005 - Practical Activities - 1hb - (10.91 SQM)	● Student Space (5)	
B00B - R1006 - Movement - (20.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Entry Vestibule - (15.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Dental Clinic - (20.14 SQM)	● Office (5)	
B00C - R0007 - Clerical Office - (8.45 SQM)	● Office (2)	
B00C - R0008 - Home Base - (58 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0009 - Practical Activities - 1hb - (13.21 SQM)	● Student Space (6)	
B00C - R0010 - Practical Activities - 1hb - (13.12 SQM)	● Student Space (6)	
B00C - R0011 - Home Base - (57.99 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0017 - Movement - (96.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (5.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (14.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Movement - (71.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Practical Activities - 1hb - (13.27 SQM)	● Student Space (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1002 - Home Base - (55.4 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1003 - Practical Activities - 1hb - (13.03 SQM)	● Student Space (6)	
B00C - R1004 - Home Base - (54.31 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1005 - Movement - (56.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R1008 - Home Base - (57.67 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R1009 - Practical Activities - 1hb - (13.11 SQM)	● Student Space (6)	
B00C - R9002 - Movement - (10.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (63.59 SQM) - Teaching Space: 1	● Student Space (35)	
B00D - R0002 - Home Base - (53.53 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0003 - Movement - (23.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (21.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (53.52 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0006 - Principal - (21.85 SQM)	● Office (5)	
B00D - R0007 - Deputy Principal - (15.38 SQM)	● Office (3)	
B00D - R0008 - Clerical Office - (15.91 SQM)	● Office (3)	
B00D - R0009 - Entry Vestibule - (7.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Staff Room - (48.17 SQM)	● Office (12)	
B00D - R0014 - Movement - (21.55 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Sick Bay - (13.5 SQM)	● Student Space (6)	
B00D - R0016 - Duplicating Workroom - (21.35 SQM)	● Office (5)	
B00D - R0017 - Movement - (13.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Withdrawal Space - 1hb - (26.58 SQM)	● Student Space (12)	
B00D - R0019 - Practical Activities - 1hb - (10.62 SQM)	● Student Space (4)	
B00D - R0020 - Special Programs Room - (9.08 SQM)	● Student Space (4)	
B00F - R0001 - Withdrawal Space - 1hb - (8.66 SQM)	● Student Space (4)	
B00F - R0003 - Practical Activities/Movement - 1hb - (17.93 SQM)	● Student Space (8)	
B00F - R0004 - Home Base - (59.74 SQM) - Teaching Space: 1	● Student Space (32)	
B00F - R0005 - Practical Activities/Movement - 1hb - (17.93 SQM)	● Student Space (8)	
B00F - R0006 - Home Base - (59.16 SQM) - Teaching Space: 1	● Student Space (32)	
B00F - R0007 - Withdrawal Space - 2hb - (11.42 SQM)	● Student Space (5)	
B00F - R0009 - Practical Activities/Movement - 1hb - (16.79 SQM)	● Student Space (7)	
B00F - R0010 - Home Base - (59.23 SQM) - Teaching Space: 1	● Student Space (32)	
B00F - R1001 - Withdrawal Space - 1hb - (8.66 SQM)	● Student Space (4)	
B00F - R1003 - Practical Activities/Movement - 1hb - (17.93 SQM)	● Student Space (8)	
B00F - R1004 - Home Base - (58.81 SQM) - Teaching Space: 1	● Student Space (32)	
B00F - R1005 - Practical Activities/Movement - 1hb - (17.93 SQM)	● Student Space (8)	
B00F - R1006 - Home Base - (58.23 SQM) - Teaching Space: 1	● Student Space (32)	
B00F - R1007 - Withdrawal Space - 2hb - (11.46 SQM)	● Student Space (5)	
B00F - R1009 - Practical Activities/Movement - 1hb - (16.79 SQM)	● Student Space (7)	
B00F - R1010 - Home Base - (59.24 SQM) - Teaching Space: 1	● Student Space (32)	
NS 250 14778 - NS 250 14778 - Learning Unit - Single E.S.L./Store - (38 SQM)	● Student Space (17)	
OS 601 12022 - OS 601 12022 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12331 - OS 601 12331 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 15490 - OS 601 15490 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 603 10375 - OS 603 10375 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	