

## VENTILATION AUDIT REPORT Version 2

<b>SCHOOL:</b>	<b>South Grafton High School (8406)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Clarence</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Clarence Valley</b>

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Staff Study - (26.96 SQM)	Office (6)	
B00A - R0005 - Laboratory L.S. - (87.01 SQM) - Teaching Space: 1	Student Space (48)	
B00A - R0006 - Preparation - (9.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Preparation - (29.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Laboratory L.S. - (87 SQM) - Teaching Space: 1	Student Space (48)	
B00A - R0015 - Movement - (130.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Movement - (17.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (17.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (12.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (8.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (5.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Laboratory L.S. - (93.61 SQM) - Teaching Space: 1	Student Space (52)	
B00A - R0025 - Seminar - (39.18 SQM)	Office (9)	
B00A - R1003 - General Learning Space - (67.81 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R1006 - General Learning Space - (53.19 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1007 - General Learning Space - (53.04 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1010 - General Learning Space - (53.33 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1011 - General Learning Space - (53.92 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1012 - Study Space - (26.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - Movement - (6.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - Staff Study - (27.03 SQM)	Office (6)	
B00A - R1017 - Movement - (134.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (10.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (18.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (318.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Movement - (19.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Movement - (10.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Movement - (149.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Movement - (7.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Canteen - (45.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Materials Technology L.S. - (89.52 SQM) - Teaching Space: 1	Student Space (49)	
B00C - R0008 - Computer Learning Space - (80.92 SQM) - Teaching Space: 1	Student Space (44)	
B00C - R0009 - Seminar/Technology Space - (9.21 SQM)	Office (2)	
B00C - R0010 - Seminar/Technology Space - (9.17 SQM)	Office (2)	
B00C - R0013 - Movement - (95.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Movement - (5.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (15.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Visual Arts Workshop - (53.06 SQM)	Student Space (24)	
B00C - R1003 - Staff Study - (26.7 SQM)	Office (6)	
B00C - R1005 - Art Learning Space - (80.33 SQM) - Teaching Space: 1	Student Space (44)	
B00C - R1007 - Darkroom Space - (19.41 SQM)	Office (4)	
B00C - R1008 - Art Learning Space - (81.22 SQM) - Teaching Space: 1	Student Space (44)	
B00C - R1011 - Movement - (102.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - General Learning Space - (54.07 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0004 - General Learning Space - (66.8 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0006 - General Learning Space - (52.46 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0007 - Commonroom - (93.71 SQM)	Office (23)	
B00D - R0009 - Staff Study - (27 SQM)	Office (6)	
B00D - R0013 - Movement - (14.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Interview/Office - Type 2 - (16.43 SQM)	Office (4)	
B00D - R0018 - Movement - (5.13 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0022 - Movement - (19.24 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Movement - (78.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Movement - (19.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Computer Learning Space - (54.15 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1003 - Materials Technology L.S. - (66.72 SQM) - Teaching Space: 1	● Student Space (36)	
B00D - R1006 - Computer Learning Space - (66.25 SQM) - Teaching Space: 1	● Student Space (36)	
B00D - R1008 - Computer Learning Space - (53.26 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R1010 - Materials Technology L.S. - (54.15 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1014 - Movement - (115.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Administration - Clerical - (18.74 SQM)	● Office (4)	
B00E - R0010 - Administration - Clerical - (14.37 SQM)	● Office (3)	
B00E - R0011 - Deputy Principal Office - (13.97 SQM)	● Office (3)	
B00E - R0015 - Administration - Clerical - (19.17 SQM)	● Office (4)	
B00E - R0016 - Principal Office - (18.29 SQM)	● Office (4)	
B00E - R0023 - Movement - (12.4 SQM)	Not Applicable	Circulation or storage space.
B00E - R0032 - Movement - (30.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0034 - Clinic - Boys - (9.97 SQM)	● Office (2)	
B00E - R0035 - Clinic - Girls - (11.04 SQM)	● Office (2)	
B00E - R0037 - Interview/Office - Type 1 - (12.63 SQM)	● Office (3)	
B00E - R0041 - Interview/Office - Type 1 - (14.12 SQM)	● Office (3)	
B00E - R0042 - Administration - Clerical - (52.82 SQM)	● Office (13)	
B00E - R0043 - Public Reception - (34.91 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (16.62 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Food Technology L.S. - (81.59 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R0016 - Movement - (116.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Movement - (14.06 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (7.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Movement - (7.21 SQM)	Not Applicable	Circulation or storage space.
B00F - R0023 - Kitchen - Type 1 - (79.93 SQM)	● Student Space (37)	
B00F - R0025 - Seminar - (25.2 SQM)	● Office (6)	
B00F - R0027 - General Learning Space - (61.25 SQM) - Teaching Space: 1	● Student Space (34)	
B00F - R1001 - Staff Study - (13.42 SQM)	● Office (3)	
B00F - R1002 - Interview/Office - Type 1 - (13.43 SQM)	● Office (3)	
B00F - R1004 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R1005 - General Learning Space - (53.48 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R1007 - General Learning Space - (53.48 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R1011 - General Learning Space - (53.48 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R1013 - General Learning Space - (53.55 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R1014 - Staff Study - (40.79 SQM)	● Office (10)	
B00F - R1017 - Movement - (124.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Wood Technology L.S. - (100.32 SQM) - Teaching Space: 1	● Student Space (55)	
B00G - R0007 - Movement - (50.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Design L.S. - (67.26 SQM) - Teaching Space: 1	● Student Space (37)	
B00H - R0001 - Laboratory L.S. - (91.27 SQM) - Teaching Space: 1	● Student Space (50)	
B00H - R0002 - Preparation - (48.34 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Laboratory L.S. - (91.25 SQM) - Teaching Space: 1	● Student Space (50)	
B00H - R0005 - Movement - (6.35 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Movement - (54.3 SQM)	Not Applicable	Circulation or storage space.
B00H - R1001 - General Learning Space - (67.5 SQM) - Teaching Space: 1	● Student Space (37)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R1002 - General Learning Space - (63.72 SQM) - Teaching Space: 1	● Student Space (35)	
B00H - R1004 - Staff Study - (31.59 SQM)	● Office (7)	
B00H - R1005 - General Learning Space - (67.5 SQM) - Teaching Space: 1	● Student Space (37)	
B00H - R1006 - Movement - (62.38 SQM)	Not Applicable	Circulation or storage space.
B00H - R9003 - Movement - (28.86 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Wood Technology L.S. - (148.76 SQM) - Teaching Space: 1	● Student Space (83)	
B00L - M0001 - Main Area - (155.72 SQM)	Not Applicable	Circulation or storage space.
B00L - M9001 - Movement - (8.77 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (14.76 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Workroom - (46.38 SQM)	● Office (11)	
B00L - R0007 - Seminar - (51.89 SQM)	● Office (12)	
B00L - R0009 - Seminar - (22.83 SQM)	● Office (5)	
B00L - R0010 - Entry - (73 SQM)	Not Applicable	Circulation or storage space.
B00L - R0012 - Main Area - (235.32 SQM)	Not Applicable	Circulation or storage space.
B00L - R0013 - Movement - (20.08 SQM)	Not Applicable	Circulation or storage space.
B00L - R0015 - Movement - (5.77 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (9.95 SQM)	Not Applicable	Circulation or storage space.
B00L - R9001 - General Assistants - (87.21 SQM)	● Office (21)	
B00L - R9003 - Movement - (8.93 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - General Learning Space - (48.03 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R0002 - Staff Study - (18.78 SQM)	● Office (4)	
B00M - R0003 - General Learning Space - (47.96 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R0004 - General Learning Space - (48.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R0006 - General Learning Space - (47.9 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R0009 - Movement - (102.93 SQM)	Not Applicable	Circulation or storage space.
B00M - R1001 - General Learning Space - (47.62 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R1002 - Seminar - (18.54 SQM)	● Office (4)	
B00M - R1003 - General Learning Space - (47.98 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R1004 - General Learning Space - (48.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R1005 - Seminar - (15.54 SQM)	● Office (3)	
B00M - R1006 - General Learning Space - (47.69 SQM) - Teaching Space: 1	● Student Space (26)	
B00M - R1009 - Movement - (96.56 SQM)	Not Applicable	Circulation or storage space.
B00N - R0003 - Wood Technology Bay - (29.32 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Workshop - (92.12 SQM)	● Student Space (42)	
BMPU - R0005 - Staff Kitchen - (17.82 SQM)	● Office (4)	
BMPU - R0007 - Public Entry - (69.54 SQM)	Not Applicable	Circulation or storage space.
BMPU - R0009 - Multi-Purpose Space - (464.31 SQM)	● Student Space (215)	
BMPU - R0016 - Movement - (16.93 SQM)	Not Applicable	Circulation or storage space.
BMPU - R0021 - Stage - (118.21 SQM)	Not Applicable	Circulation or storage space.
OS 601 12094 - OS 601 12094 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 711 12307 - OS 711 12307 - Home Science/Art/Science Dem/Computer - (95 SQM)	● Student Space (44)	