

<b>SCHOOL:</b>	<b>Tamworth Public School (3157)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Tamworth</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Tamworth</b>

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (13.01 SQM)	Office (3)	
B00A - R0002 - Staff Room Annexe - (10.32 SQM)	Office (2)	
B00A - R0004 - Home Base - (70.12 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R0005 - Movement - (5.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Entry Vestibule - (22.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (5.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Principal - (19.85 SQM)	Office (4)	
B00A - R0016 - Deputy Principal - (14.06 SQM)	Office (3)	
B00A - R0017 - Movement - (59.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Home Base - (45.07 SQM) - Teaching Space: 1	Student Space (48)	
B00A - R0023 - Home Base - (45.07 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R0024 - Staff Room Annexe - (11.09 SQM)	Office (2)	
B00A - R0025 - Home Base - (45.07 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R0026 - Home Base - (45.4 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R0027 - Home Base - (45.4 SQM) - Teaching Space: 1	Student Space (48)	
B00A - R0028 - Movement - (71.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Movement - (36.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Movement - (15.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Home Base - (46.55 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0037 - Home Base - (47.89 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R0038 - Movement - (30.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Staff Room - (22.17 SQM)	Office (5)	
B00A - R0040 - Principal - (17.08 SQM)	Office (4)	
B00A - R0041 - Clerical Office - (42.21 SQM)	Office (10)	
B00A - R0042 - Sick Bay - (8.07 SQM)	Student Space (4)	
B00A - R0043 - Movement - (23.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Home Base - (58.81 SQM) - Teaching Space: 1	Student Space (67)	
B00A - R0047 - Movement - (22.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0056 - Staff Room - (87.77 SQM)	Office (21)	
B00A - R0057 - Staff Kitchen - (14 SQM)	Office (3)	
B00A - R0059 - Clerical/Printing - (10.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0060 - Study Annexe - (29.36 SQM)	Office (7)	
B00A - R1001 - Home Base - (54.45 SQM) - Teaching Space: 1	Student Space (32)	
B00A - R1002 - Staff Room Annexe - (24.48 SQM)	Office (6)	
B00A - R1003 - Movement - (19.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Staff Room Annexe - (33.85 SQM)	Office (8)	
B00A - R9012 - Movement - (30.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R9015 - Movement - (22.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R9016 - Movement - (24.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R9017 - Practical Activities - 1hb - (45.95 SQM)	Student Space (45)	
B00A - R9018 - Home Base - M - (45.96 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0001 - Staff Room Annexe - (19.53 SQM)	Office (4)	
B00B - R0002 - Duplicating Workroom - (9.38 SQM)	Office (2)	
B00B - R0004 - Home Base - M - (40.1 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0005 - Practical Activities - M - 1hb - (12.19 SQM)	Student Space (29)	
B00B - R0006 - Home Base - (35.1 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0007 - Practical Activities - 1hb - (11.2 SQM)	Student Space (29)	
B00B - R0008 - Home Base - (35.1 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0009 - Practical Activities - 1hb - (11.19 SQM)	● Student Space (29)	
B00B - R0010 - Movement - (7.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Staff Room Annexe - (18.6 SQM)	● Office (4)	
B00B - R0012 - Communal Space - (138.7 SQM)	● Student Space (73)	
B00B - R0016 - Practical Activities - 1hb - (14.43 SQM)	● Student Space (31)	
B00B - R0017 - Home Base - (32.3 SQM) - Teaching Space: 1	● Student Space (16)	
B00B - R0018 - Practical Activities - 1hb - (14.44 SQM)	● Student Space (16)	
B00B - R0019 - Home Base - (32.3 SQM) - Teaching Space: 1	● Student Space (14)	
B00B - R0020 - Movement - (56.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (56.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Special Programs Room - (42.72 SQM)	● Student Space (19)	
B00C - R0007 - Reading Area - (219.26 SQM)	● Student Space (101)	
B00C - R0008 - Movement - (14.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (14.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (62.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (49.86 SQM) - Teaching Space: 1	● Student Space (43)	
B00D - R0004 - Home Base - (157.35 SQM) - Teaching Space: 1	● Student Space (88)	
B00D - R0005 - Home Base - (51.17 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0006 - Home Base - (52.65 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0010 - Movement - (6.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Movement - (22.83 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Home Base - (107.23 SQM) - Teaching Space: 1	● Student Space (58)	
B00D - R0013 - Movement - (20.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Special Programs Room - (50.67 SQM)	● Student Space (23)	
B00E - R0003 - Movement - (15.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Canteen - (30.13 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Withdrawal Space - 1hb - (20.65 SQM)	● Student Space (22)	
B00F - R0005 - Home Base - (47.23 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0006 - Home Base - (47.24 SQM) - Teaching Space: 1	● Student Space (25)	
B00F - R0007 - Home Base - (47.74 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0008 - Home Base - (47.74 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0012 - Movement - (79.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Staff Room Annexe - (15.67 SQM)	● Office (3)	
B00F - R1001 - Movement - (85.4 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - Home Base - (48.26 SQM) - Teaching Space: 1	● Student Space (39)	
B00F - R1003 - Home Base - (48.07 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R1004 - Home Base - (48.62 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R1005 - Home Base - (48.62 SQM) - Teaching Space: 1	● Student Space (44)	
B00F - R1006 - Staff Room Annexe - (23.07 SQM)	● Office (5)	
B00G - R0001 - Staff Room Annexe - (50.77 SQM)	● Office (12)	
B00G - R0002 - Staff Kitchen - (25.22 SQM)	● Office (6)	
B00G - R0007 - Staff Room - (64.26 SQM)	● Office (16)	
B00H - R0003 - Movement - (7.23 SQM)	Not Applicable	Circulation or storage space.
B00O - R0001 - Communal Space - (361.49 SQM)	● Student Space (167)	
B00O - R0002 - Clerical Office - (13.24 SQM)	● Office (3)	
B00O - R0004 - Staff Kitchen - (20.21 SQM)	● Office (5)	
B00O - R0005 - Movement - (17.09 SQM)	Not Applicable	Circulation or storage space.
B00O - R0020 - Movement - (11.06 SQM)	Not Applicable	Circulation or storage space.
B00O - R0021 - Outdoor Learning Area - (257.82 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Home Base - (69 SQM) - Teaching Space: 1	● Student Space (32)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R0002 - Home Base - (63.58 SQM) - Teaching Space: 1	● Student Space (57)	
B00P - R0006 - Withdrawal Space - 1hb - (9.23 SQM)	● Student Space (4)	
B00P - R0007 - Withdrawal Space - 1hb - (9.16 SQM)	● Student Space (4)	
B00P - R0009 - Practical Activities - 2hb - (66.91 SQM)	● Student Space (31)	
B00P - R0010 - Presentation Area - (61.23 SQM)	Not Applicable	Circulation or storage space.
B00P - R0013 - Outdoor Learning Area - (163.19 SQM)	Not Applicable	Circulation or storage space.
B00P - R1001 - Home Base X3 - (155.79 SQM) - Teaching Space: 3	● Student Space (72)	
B00P - R1002 - Practical Activities - 3hb - (65.11 SQM)	● Student Space (30)	
B00P - R1006 - Staff Room Annexe - (6.73 SQM)	● Office (1)	
B00P - R1007 - Withdrawal Space - 2hb - (18.6 SQM)	● Student Space (8)	
B00P - R1009 - Presentation Area - (56.52 SQM)	Not Applicable	Circulation or storage space.
B00P - R1010 - Home Base - (42.31 SQM) - Teaching Space: 1	● Student Space (29)	
B00P - R1013 - Withdrawal Space - 2hb - (16.2 SQM)	● Student Space (14)	
B00P - R1016 - Outdoor Learning Area - (120.86 SQM)	Not Applicable	Circulation or storage space.
NS 100 14346 - NS 100 14346 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (83)	
OS 602 10783 - OS 602 10783 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13712 - OS 602 13712 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (83)	
OS 602 14237 - OS 602 14237 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 11614 - OS 603 11614 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 12663 - OS 603 12663 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	