


# VENTILATION AUDIT REPORT Version 2

<b>SCHOOL:</b>	<b>Tucabia Public School (3263)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Clarence</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Clarence Valley</b>



Site plan is indicative only and is included to show building numbers used by the Department.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (11.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Staff Room - (30.89 SQM)	 Office (7)	
B00A - R0005 - Principal - (14.49 SQM)	 Office (3)	
B00A - R0006 - Clerical Office/Workroom - (16.55 SQM)	 Office (4)	
B00A - R0012 - Movement - (7.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Clerical Office/Workroom - (27.29 SQM)	 Office (6)	
B00A - R0014 - Movement - (14.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Clerical Office - (13.72 SQM)	 Office (3)	
B00B - R0002 - Practical Activities - 1hb - (31.66 SQM)	 Student Space (14)	
B00B - R0003 - Home Base - (71.49 SQM) - Teaching Space: 1	 Student Space (56)	
B00B - R0005 - Movement - (11.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Withdrawal Space - 1hb - (11.08 SQM)	 Student Space (5)	
B00B - R0009 - Movement - (24.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (34.57 SQM) - Teaching Space: 1	 Student Space (42)	
B00C - R0002 - Practical Activities - 1hb - (11.63 SQM)	 Student Space (5)	
B00C - R0003 - Withdrawal Space - 1hb - (14.69 SQM)	 Student Space (6)	
B00C - R0005 - Movement - (14.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Communal Space - (28.15 SQM)	 Student Space (13)	
B00E - R0003 - Movement - (29.71 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (14.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Home Base - (59.05 SQM) - Teaching Space: 1	 Student Space (38)	
B00F - R0003 - Practical Activities - 1hb - (14.17 SQM)	 Student Space (6)	
B00F - R0005 - Withdrawal Space - 1hb - (11.48 SQM)	 Student Space (5)	
B00F - R0006 - Home Base - (59.04 SQM) - Teaching Space: 1	 Student Space (38)	
B00F - R0008 - Practical Activities - 1hb - (14.17 SQM)	 Student Space (6)	
B00F - R0009 - Movement - (14.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Movement - (33.09 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Canteen - (13.75 SQM)	Not Applicable	Circulation or storage space.