


VENTILATION AUDIT REPORT Version 2

SCHOOL:	Walla Walla Public School (3352)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Albury
LOCAL GOVERNMENT AREA:	Greater Hume

3352 - Walla Walla Public School
Site Plan (11370)



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (45.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical Office - (23.21 SQM)	Office (5)	
B00A - R0003 - Entry Vestibule - (12.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Principal - (12.08 SQM)	Office (3)	
B00A - R0007 - Movement - (5.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Practical Activities - 1hb - (41.38 SQM)	Student Space (19)	
B00A - R0010 - Home Base - (56.44 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0013 - Withdrawal Space - 1hb - (10.44 SQM)	Student Space (4)	
B00A - R0015 - Home Base - (55.96 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0023 - Home Base - (56.43 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0025 - Withdrawal Space - 1hb - (10.38 SQM)	Student Space (4)	
B00A - R0028 - Home Base - (56.5 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0029 - Movement - (52.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Practical Activities - 1hb - (41.39 SQM)	Student Space (19)	
B00A - R0034 - Movement - (8.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Sick Bay - (8.19 SQM)	Student Space (3)	
B00A - R0037 - Movement - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Staff Room - (30.57 SQM)	Office (7)	
B00B - R0002 - Movement - (30.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Reading Area - (77.48 SQM)	Student Space (35)	
B00E - R0001 - Canteen - (13.36 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Withdrawal Space - 1hb - (17.68 SQM)	Student Space (8)	