


VENTILATION AUDIT REPORT Version 2

SCHOOL:	Waratah Public School (3377)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Wallsend
LOCAL GOVERNMENT AREA:	Newcastle



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (6.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical Office - (12.96 SQM)	Office (3)	
B00A - R0003 - Sick Bay - (8.48 SQM)	Student Space (3)	
B00A - R0004 - Entry Vestibule - (18.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Clerical Office - (13.74 SQM)	Office (3)	
B00A - R0006 - Duplicating Workroom - (14.79 SQM)	Office (3)	
B00A - R0007 - Movement - (25.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Principal - (22.54 SQM)	Office (5)	
B00A - R0012 - Staff Room Annexe - (13.9 SQM)	Office (3)	
B00A - R0013 - Staff Room - (75.08 SQM)	Office (18)	
B00A - R0016 - Movement - (15.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Deputy Principal - (17.21 SQM)	Office (4)	
B00A - R0018 - Interview - (12.53 SQM)	Office (3)	
B00A - R0019 - Movement - (37.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Entry Vestibule - (19.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (46.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Special Programs Room - (61.38 SQM)	Student Space (28)	
B00B - R0016 - Reading Area - (203.93 SQM)	Student Space (94)	
B00C - R0001 - Movement - (89.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (48.23 SQM) - Teaching Space: 1	Student Space (127)	
B00C - R0005 - Practical Activities - 1hb - (21.28 SQM)	Student Space (9)	
B00C - R0006 - Home Base - (48.37 SQM) - Teaching Space: 1	Student Space (127)	
B00C - R0007 - Practical Activities - 1hb - (21.28 SQM)	Student Space (9)	
B00C - R0012 - Home Base - (48.7 SQM) - Teaching Space: 1	Student Space (127)	
B00C - R0013 - Practical Activities - 1hb - (20.95 SQM)	Student Space (9)	
B00C - R0014 - Home Base - (48.12 SQM) - Teaching Space: 1	Student Space (127)	
B00C - R0015 - Practical Activities - 1hb - (21.27 SQM)	Student Space (9)	
B00C - R0016 - Movement - (19.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (49.13 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Practical Activities - 1hb - (7.13 SQM)	Student Space (3)	
B00D - R0004 - Home Base - (80.82 SQM) - Teaching Space: 1	Student Space (148)	
B00D - R0005 - Practical Activities - 1hb - (7.29 SQM)	Student Space (3)	
B00D - R0007 - Home Base - (79.24 SQM) - Teaching Space: 1	Student Space (148)	
B00D - R0009 - Practical Activities - 1hb - (6.95 SQM)	Student Space (3)	
B00D - R0010 - Home Base - (80.88 SQM) - Teaching Space: 1	Student Space (148)	
B00D - R0012 - Movement - (43.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Practical Activities - 1hb - (21.31 SQM)	Student Space (9)	
B00E - R0002 - Home Base - (47.75 SQM) - Teaching Space: 1	Student Space (120)	
B00E - R0003 - Practical Activities - 1hb - (21.39 SQM)	Student Space (9)	
B00E - R0004 - Home Base - (48.21 SQM) - Teaching Space: 1	Student Space (120)	
B00E - R0005 - Movement - (127.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Home Base - (47.7 SQM) - Teaching Space: 1	Student Space (120)	
B00E - R0011 - Practical Activities - 1hb - (21.23 SQM)	Student Space (9)	
B00E - R0012 - Home Base - (47.34 SQM) - Teaching Space: 1	Student Space (111)	
B00E - R0013 - Practical Activities - 1hb - (21.07 SQM)	Student Space (9)	
B00E - R0014 - Home Base - (47.46 SQM) - Teaching Space: 1	Student Space (82)	
B00E - R0015 - Practical Activities - 1hb - (21.1 SQM)	Student Space (9)	
B00E - R0016 - Home Base - E - (48.47 SQM) - Teaching Space: 1	Student Space (82)	
B00E - R0017 - Practical Activities - E - (14.55 SQM)	Student Space (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0002 - Movement - (57.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Raised Platform - (47.24 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Movement - (61.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Canteen - (39.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Special Programs Room - (92.35 SQM)	● Student Space (42)	
B00F - R0021 - Special Programs Room - (83.51 SQM)	● Student Space (38)	
B00G - R0003 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Movement - (5.45 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Practical Activities - 1hb - (17.58 SQM)	● Student Space (8)	
B00G - R0009 - Home Base - (47.25 SQM) - Teaching Space: 1	● Student Space (34)	
B00G - R0010 - Practical Activities - 1hb - (17.75 SQM)	● Student Space (8)	
B00G - R0011 - Home Base - (47.04 SQM) - Teaching Space: 1	● Student Space (34)	
B00G - R0013 - Movement - (46.25 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Staff Room Annexe - (15.32 SQM)	● Office (3)	
B00G - R0017 - Practical Activities - 1hb - (18.02 SQM)	● Student Space (8)	
B00G - R0018 - Home Base - (47.73 SQM) - Teaching Space: 1	● Student Space (34)	
B00G - R0021 - Practical Activities - 1hb - (17.58 SQM)	● Student Space (8)	
B00G - R0022 - Home Base - (47.47 SQM) - Teaching Space: 1	● Student Space (34)	
B00G - R0023 - Movement - (15.37 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Movement - (12.92 SQM)	Not Applicable	Circulation or storage space.
B00G - R1003 - Practical Activities - 1hb - (18.8 SQM)	● Student Space (8)	
B00G - R1004 - Home Base - (48.33 SQM) - Teaching Space: 1	● Student Space (34)	
B00G - R1005 - Practical Activities - 1hb - (18.61 SQM)	● Student Space (8)	
B00G - R1006 - Home Base - (47.95 SQM) - Teaching Space: 1	● Student Space (34)	
B00G - R1007 - Withdrawal Space - 1hb - (39.53 SQM)	● Student Space (18)	
B00G - R1008 - Movement - (27.03 SQM)	Not Applicable	Circulation or storage space.
B00G - R1009 - Practical Activities - 1hb - (18.4 SQM)	● Student Space (8)	
B00G - R1010 - Home Base - (48.45 SQM) - Teaching Space: 1	● Student Space (34)	
B00G - R1011 - Practical Activities - 1hb - (18.97 SQM)	● Student Space (8)	
B00G - R1012 - Home Base - (48.39 SQM) - Teaching Space: 1	● Student Space (34)	
B00G - R1013 - Withdrawal Space - 1hb - (12.93 SQM)	● Student Space (5)	
B00H - R0002 - Movement - (84.69 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Home Base - Pre - (76.13 SQM) - Teaching Space: 1	● Student Space (145)	
B00H - R0010 - Movement - (8.27 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Home Base - Pre - (76.41 SQM) - Teaching Space: 1	● Student Space (163)	
B00H - R0016 - Movement - (12.04 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Communal Space - (197.97 SQM)	● Student Space (91)	
B00I - R0016 - Movement - (17.08 SQM)	Not Applicable	Circulation or storage space.
B00I - R0017 - Movement - (12.89 SQM)	Not Applicable	Circulation or storage space.
B00I - R0018 - Raised Platform - (58.27 SQM)	Not Applicable	Circulation or storage space.
B00I - R0019 - Movement - (6.54 SQM)	Not Applicable	Circulation or storage space.