

SCHOOL:	Wee Waa High School (8270)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Narrabri

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clinic - Girls - (12.27 SQM)	Office (3)	
B00A - R0004 - Staff Study - (11.12 SQM)	Office (2)	
B00A - R0005 - Movement - (29.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Administration - Clerical - (31.45 SQM)	Office (7)	
B00A - R0007 - Duplicating Workroom - (28.68 SQM)	Office (7)	
B00A - R0008 - Principal Office - (22.82 SQM)	Office (5)	
B00A - R0009 - Interview/Office - Type 1 - (11.68 SQM)	Office (2)	
B00A - R0010 - Deputy Principal Office - (18.18 SQM)	Office (4)	
B00A - R0011 - Movement - (32.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Seminar - (15.33 SQM)	Office (3)	
B00A - R1002 - Commonroom - (66.72 SQM)	Office (16)	
B00A - R1005 - Movement - (15.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - Staff Study - (30.54 SQM)	Office (7)	
B00A - R1010 - Movement - (30.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Multi-Purpose Space - (323.34 SQM)	Student Space (150)	
B00B - R0006 - Stage - (49.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Movement - (45.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (82.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R1005 - Movement - (45.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Metal Technology L.S. - (112.74 SQM) - Teaching Space: 1	Student Space (62)	
B00C - R0007 - Movement - (7.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Darkroom Space - (6.03 SQM)	Office (1)	
B00C - R0015 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Art Learning Space - (80.21 SQM) - Teaching Space: 1	Student Space (44)	
B00C - R0022 - Movement - (228.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Student Canteen - (30.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Design L.S. - (87.1 SQM) - Teaching Space: 1	Student Space (48)	
B00C - R1004 - Staff Study - (26.61 SQM)	Office (6)	
B00C - R1006 - Staff Study - (24.67 SQM)	Office (6)	
B00C - R1007 - Computer Learning Space - (51.22 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1008 - General Learning Space - (50.85 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1009 - General Learning Space - (50.86 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1010 - General Learning Space - (50.86 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1011 - General Learning Space - (50.5 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1012 - General Learning Space - (50.86 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1013 - Movement - (184.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - General Learning Space - (88.84 SQM) - Teaching Space: 1	Student Space (49)	
B00D - R0002 - Laboratory L.S. - (104.74 SQM) - Teaching Space: 1	Student Space (58)	
B00D - R0008 - Movement - (15.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Food Technology L.S. - (115.5 SQM) - Teaching Space: 1	Student Space (53)	
B00D - R0012 - Hospitality Space - (38.79 SQM)	Student Space (17)	
B00D - R0015 - Food/Research Space - (15.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Staff Study - (11.65 SQM)	Office (2)	
B00D - R1002 - Main Area - (247.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R1004 - Audio Visual Workroom - (17.73 SQM)	Student Space (8)	
B00D - R1005 - Workroom - (25.64 SQM)	Office (6)	
B00D - R1008 - Seminar - (23.38 SQM)	Office (5)	
B00D - R1014 - Movement - (8.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R1015 - Movement - (77.83 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0002 - Movement - (8.25 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Gymnasium - (196.3 SQM)	● Student Space (91)	
B00H - R0001 - General Learning Space - (45.08 SQM) - Teaching Space: 1	● Student Space (20)	
B00I - R0001 - General Learning Space - (59.9 SQM) - Teaching Space: 1	● Student Space (32)	
B00I - R0002 - Science Laboratory - (59.98 SQM)	● Student Space (27)	
B00I - R0003 - Preparation - (31.01 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Staff Study - (21.08 SQM)	● Office (5)	
B00I - R0007 - Seminar - Type 2 - (21.14 SQM)	● Office (5)	
B00I - R0008 - Movement - (6.38 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - General Learning Space - (34.35 SQM) - Teaching Space: 1	● Student Space (18)	
B00J - R0002 - Staff Study - (33.25 SQM)	● Office (8)	
B00J - R0004 - General Learning Space - (34.35 SQM) - Teaching Space: 1	● Student Space (15)	
B00L - R0003 - General Assistants - (14.14 SQM)	● Office (3)	
OS 502 11861 - OS 502 11861 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	
OS 505 10403 - OS 505 10403 - Admin Staff/Principal/Secure Store - (76 SQM)	● Office (19)	
OS 601 11611 - OS 601 11611 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11611 - OS 601 11611 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11611 - OS 601 11611 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11611 - OS 601 11611 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12558 - OS 601 12558 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12558 - OS 601 12558 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12558 - OS 601 12558 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12558 - OS 601 12558 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13796 - OS 601 13796 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13964 - OS 601 13964 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13970 - OS 601 13970 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 16214 - OS 601 16214 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 16214 - OS 601 16214 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 16214 - OS 601 16214 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 16214 - OS 601 16214 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 15276 - OS 602 15276 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 710 11933 - OS 710 11933 - Home Science/Pantry/Laundry - (95 SQM)	● Office (23)	
OS 720 15935 - OS 720 15935 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 19104 - OS 720 19104 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 760 10897 - OS 760 10897 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 760 15010 - OS 760 15010 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 770 14451 - OS 770 14451 - Technics - Metalwork/Heat Area/Store - (76 SQM)	Not Applicable	Circulation or storage space.