

# VENTILATION AUDIT REPORT Version 2

<b>SCHOOL:</b>	<b>Woodstock Public School (3499)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Cootamundra</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Cowra</b>

3499 - Woodstock Public School  
Site Plan (11467)



Site plan is indicative only and is included to show building numbers used by the Department.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0002 - Reading Area - (45.92 SQM)	 Student Space (21)	
B00B - R0003 - Home Base - (45.85 SQM) - Teaching Space: 1	 Student Space (25)	
B00B - R0004 - Home Base - (46.31 SQM) - Teaching Space: 1	 Student Space (25)	
B00B - R0005 - Principal - (10.58 SQM)	 Office (2)	
B00B - R0006 - Movement - (31.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Practical Activities - (31.92 SQM)	 Student Space (14)	
B00E - R0001 - Movement - (15.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (42.35 SQM) - Teaching Space: 1	 Student Space (23)	
B00F - R0001 - Reading Area - (59.86 SQM)	 Student Space (27)	
B00G - R0002 - Practical Activities - (16.88 SQM)	 Student Space (7)	
OS 505 11236 - OS 505 11236 - Admin Staff/Principal/Secure Store - (76 SQM)	 Office (19)	